

Full Title of the Project: - Re-routing of 400 KV Single Circuit Dul Hasti Kishanpur transmission Line from Tower 43 to 47 in Drabshalla Kishtwar.

File No. : - FP/JK/TRANS/140816/2021.

Date of Proposal: - 09-04-2021.

CHECK LIST SERIAL NUMBER- 16

SITE INSPECTION REPORT NOT BELOW THE RANK OF DCF
(For the Forest Land to be diverted under FCA)

A proposal has been received by this office from Power Grid Corporation of India Limited (Batote) for the diversion (under FCA-1980) of 6.003 ha. of forest for non forestry purpose. The subject envisages the use of forest land for Re-routing of 400 KV Single Circuit Dul Hasti Kishtwar Transmission Line from Tower 43 to 47 of Drabshalla Kishtwar. The site inspection of the land involved in the proposal has been done by me on dated 29-07-2020.

On inspection of the site, it is found that the land required by the user agency is a forest measuring 6.003 ha.

The requirement of forest land as proposed by the user agency in col. 2 of part-1 is unavoidable and is barest minimum required for the project.

Whether any rare / endangered / unique species of the flora and fauna found in the area. If so, the details thereof.

_____NO_____

Whether any protected archaeological / heritage site / defense establishment or any other important monument is located in the area . If so, the details thereof with NOC from the competent authority, if required.

_____NO_____

The user agency has not violated the provision of forest (Conservation) Act 1980 and no work has been started without proper sanction.

_____Yes_____

It has been found that the user agency has violated the forest (Conservation) Act 1980 provisions. A detailed report as per Para 1.9 of Chapter 1. Part C of Hand book of Forest (Conservation) Act, 1980 is attached.

(Note: Whichever of the above is applicable should be shown bold letters).

Specific recommendation for acceptance or otherwise of the proposal.

Due to a major landslide in Drabshalla area (Bumshroo top) near 83rd Kms of NH-244, tower No. 44 of the 400 KV Single circuit Dulhasti Transmission line has become un-stable and may collapse at any time. As such in order to avoid any un-toward incident and to ensure un-interrupted power supply from the Generating system, the present proposed line is recommended to be accepted.

Date....05-10-2020

Place. KISHITWAR

Name: Jagan Singh

Designation: D.F.O.

Office Seal _____

Divisional Forest Officer
Forest Division Kishtwar