

INSPECTION REPORT

The proposal area for diversion is 0.0768 Ha in Kanguzhi RF and Thirukonam RF in Ariyalur Range of Ariyalur Forest Division.

I have inspected the Kanguzhi RF & Thirukonam RF and the proposed area for erection of 11 KV feeder (HT) feeder (HT) EB posts from Ayyur to Pukkuzhi village via Silampur across Kankuli R.F and Thirukkonam R.F on 13.10.2021 along with the District Forest Officer, Ariyalur and E.B officials.

The proposed linear alignment of Electricity line runs along the existing Panchayat road in 2 stretches.

1. Ayyur to Silambur road passing through – Kanguzhi R.F for a length of – 420 m – 27 poles will be erected along this stretch.
2. Silabmur to Pukkuzhi road passing through – Thirukonam R.F for a length of – 300 m

The actual requirement is calculated as follows:-

Electricity line length in 2 stretches	-	720 m	= 768.096 m ²
Required width	-	1.0668m	
Area required	-	0.0768 Ha	

The proposed alignment passes along the existing Panchayat road which runs through the above Reserve Forests. There are no trees or natural vegetation along the proposed alignment.

The Reserve Forests are already leased out to Tamil Nadu Plantation Corporation for raising Eucalyptus tereticornis and Cashew from the year 1974.

Therefore there is no objection from Forestry and Wildlife point of view. Since the proposed electricity line will provide electricity to around 10 villages which would be beneficial for the development of the villages.

The proposed area is bare minimum and it is not part of any wildlife sanctuary and wildlife corridor. There is no alternate land is available.

Hence I recommend the proposal.

13.10.21
Chief Conservator of Forests,
Trichy Circle.

13/10/21

13.10.21

17/10/21