

FIELD INSPECTION NOTES OF DISTRICT FOREST OFFICER,
RANGAREDDY IN SRINAGAR RESERVE FOREST ON
01.11.2021

I have inspected the proposed area for Diversion of 1.9716 Ha of Forest Land for the erection of 132 KV DC/SC overhead lines from 220/132 KV Fabcity to proposed 132/33 KV Kandukur substation in favour of TSTRANSCO in Srinagar RF along with Forest Range Officer, Mankhal and staff of Mankhal Range.

The proposed forest land situated in the Compt. Nos.332 in Srinagar RF of Mankhal Range of Shamshabad Division in Ranga Reddy District. The total length of proposed line is 730.24 Mtrs with a width of 27 mtrs passing through RF Srinagar and the total area comes to 1.9716 Ha. It is observed that 72 Nos Teak and 265 Nos Non Teak trees are falling in the proposed diversion area, I have test checked the enumeration list and found correct. the predominant species observed is Jacaranda Mimosifolia. The other flora existing in this area are Ficus Religiosa, Tectonagrandis and Tabubia etc., The height of the species varies from 1.5 Mtrs to 6 Mtrs. During enquiry with the staff, the fauna present in the area consists of mostly Wild Bores of Schedule (III) animals of Wildlife (Protection) Act, 1972, which are not endangered.

District Forest Officer,
Ranga Reddy