

Part – III

(To be filled by the concerned Conservator of Forests)

14. Whether site, where the forest land involved is located has been inspected by Concerned Conservator of Forests (Yes/No). If yes, the date of inspection & observations made in from of inspection note to be enclosed : Yes.
24-03-2017
Site inspection report attached.

15. Whether the concerned Conservator of Forests agree with the information given in Part – B and the recommendations of Deputy Conservator of Forests : No

16. Specific recommendation of concerned Conservator of Forests for acceptance of otherwise of the proposal with detailed reasons : Inspected the site on 24-03-2017. The proposal is for laying 120m LT single phase 2 wire line and provide service connection to Ammayambalamchathuppu under Total electrification Scheme. The forest area is moist deciduous natural forest and it is found that the area to be diverted for providing electric line is 0.012 ha. The project involves extending the 11 KV line for providing connection to households. The project may also require installation of transformer for which no mention is made in the proposal. During my inspection it was found that through an alternate route, the requirement of forest area may be minimized. 8 SC families will be benefited by the project. The area does not have rare / endangered / threatened species and is not part of protected area under Wildlife (Protection) Act 1972. No protected archaeological / heritage site / defence establishment is located in the area. During my inspection, no work in violation of the FC Act or guidelines is seen carried out by user agency. The project is returned back to the user agency to clarify whether requirement of the forest area can be minimized by choosing an alternate alignment. The user agency may also comment on the need for installation of transformer at the site.

Date: 24-03-2017

Place : Kollam

Official Seal :

Signature : 
Name : Deepak Mishra IFS

Chief Conservator of Forests, (SC), Kollam.