

(To be filled by the concerned Conservator of Forests)

14. Whether site, where the forest land involved is located has been inspected by Concerned Conservator of Forests (Yes/No). If yes, the date of inspection & observations made in from of inspection note to be enclosed : Yes.
24-03-2017
Site inspection report attached.
15. Whether the concerned Conservator of Forests agree with the information given in Part – B and the recommendations of Deputy Conservator of Forests : Yes.
16. Specific recommendation of concerned Conservator of Forests for acceptance of otherwise of the proposal with detailed reasons : Inspected the site on 24/03/2017. The proposal is for laying 1.0 km LT single phase line through forest for electrification of Chenagiri 6 acre and 8 acre area under Total electrification Scheme. The area proposed to be diverted for providing electric line is 0.12 ha. The proposed electric line is in two bits. First bit is of 900 m length and 2nd bit is of 300 m length.
The electric line is aligned along the existing road, which passes through dense forest on both sides. The laying of electric line or subsequent maintenance will require felling or lopping of trees. The area is frequented by wild elephants. As suggested by Divisional Forest Officer, Thenmala, the user agency may consider laying UG cable to supply electricity to the house in these areas.
The project is therefore not recommended in the present form.

Date: 24-03-2017
Place : Kollam

Signature : 
24/3/17

Name : Deepak Mishra IFS

Official Seal :

Chief Conservator of Forests, (SC),
Kollam.