

**Recommendation of the  
Divisional Forest Officer, Jalpaiguri Division  
on Part A**

The diversion of land proposed is for drawal of 11 KV feeder from 33/11 KV Gayerkata Sub-station to Khuttimari Forest Rest House, under Moraghat Range for village electricity under Deen Dayal Upadhyaya Gram Jyoti Yojana under Proposal number **FP/WB/VELEC/34640/2018** is unavoidable and barest minimum requirement for the project. The proposed diversion will not hamper any soil conservation & movement of wildlife if the wire is insulated and drawn above 6.00 meter from the ground level.

The case is hereby recommended.



Divisional Forest Officer  
Jalpaiguri Division