

PART – III

(To be filled by the concerned Conservator of Forests)

14. Whether site, where the forest land involved is located has been inspected by concerned Conservator of Forests (Yes/No). If yes, the date of inspection & observation made in form of inspection note to be enclosed.

No,

15. Whether concerned Conservator of Forests agree with the information given in Part-B and the recommendations of Deputy Conservator of Forests.

Yes,

16. Specific recommendation of concerned Conservator of Forests for acceptance or otherwise of the proposal with detailed reasons.

The proposal is for diversion of 24.8509 ha. (7.9409 ha. PF and 16.91 ha. GMJJ) forest land in Hazaribagh West Forest Division for construction of 132 KV transmission line from Barhi to Itkhorri Transmission line.

The soil along the proposed transmission line is highly vulnerable to soil erosion. It has been recorded that many wild animals including Elephant have been criss crossing the proposed site because of their vicinity to Hazaribag Wildlife Sanctuary and Gautam Buddha Wildlife Sanctuary.

Hence, all precaution should be taken to avoid electrocution of wildlife especially Elephants, so ABC cables (Insulated Aerial Bundled Cables)/Underground cable should be preferred in the area. In case of overhead transmission line, the height of the transmission line be kept more than the trunk height of the Elephant.

The proposal is meant for construction and development of transmission system and also to mitigate the actual shortage of power due to non availability/inadequate capacity of transmission system in the area. A large number of people will be benefited by this project.

In view of the aforesaid facts, this proposal is being recommended for the diversion of 24.8509 ha. Forest Land for construction of 132 KV transmission line from Barhi to Itkhorri Transmission line.

Signature :



Name : J. P. Keshari, IFS
J. P. Keshari

Official seal **Conservator of Forest**
Territorial Circle-Hazaribag

Date : 27.09.2021