KARNATAKA FOREST DEPARTMENT

Office of the Deputy conservator of forests, Sirsi Division, Sirsi.

Phone:08384-226445

email:dcfsirsi@gmail.com

Date:11-04-2019

Recommendation

Sub:Diversion of 1.33 ha of forest land in f.sy.no.54a of kansur village of siddapur taluk, Uttar kannada district for establishing 1x10 MVA, 110/11 KV substation in favour of the exective engineer (Electrical), major works division, KPTCL(UK)

--0-

The project is for establishing of 1x10 MVA, 110/11 KV substation at F.sy.no.54a of Kangod(Kansur) village, This project is necessarily required to quality power supply to the public & minimize the interruption to rural area of Sirsi and Siddapur taluq. And to solve the low voltage problem, minimize the overload problem in sirsi and siddapur grid, Hence the diversion of forest land of 1.33 ha is recommended for approval. and also recommended for the lease period of 30 years.

Deputy conservator of forest Sirsi Division, Sirsi.