

(Regd. Office: PSEB Head Office, The Mall, Patiala)
Office of Chief Engineer/Transmission System
B-1, Shakti Vihar, Patiala.

Endst. No. 4485-111W-989
Dated: 4/10/17
Copy of this letter forwarded to PTA
for further necessary action

Phone: 0175-2303093 FAX: 0175-2303093 e-mail: ce-ts@pseb.org

Dy. Chief Engineer
1st Circle, PSPCL, Patiala
Memo No.

/TSR 414

Date

Subject:

Proposed Route plan of 66 KV SC line on DC towers from 66 KV S/s Ramuwala - 66 KV S/s Charik.

Ref:

Please refer to your office endst no. 3700 dtd. 03.08.17 and Endst. no. 3987 dtd. 01.09.2017.

Subject cited route plan submitted vide your letter under reference has been technically concurred with corrections/comments on drawing subject to the following conditions

1. First and last tower of the route shall be adjusted as per Gantry location at the Grid Sub-Station
2. The technical concurrence is being given strictly as per recommendations of Dy CE/TL circle Patiala & ASE/TL Div Bathinda purely on technical basis
3. The route has been technically concurred in view of certificate that route is shortest technical possible.
4. Approval of authorized person of PSTCL should be obtained for crossing of 400 KV TWS - NKS line with subject cited line at TL no. 4 - 5 before taking work in hand.
5. Approval of authorized person of PSTCL should be obtained for crossing of 400 KV TWS - NKS line with subject cited line at TL no. 16 - 17 before taking work in hand.
6. Approval of authorized person of PGCIL should be obtained for crossing of Moga - Bhiwadi line with subject cited line with at TL no 7 - 8 at your level before taking work in hand.
7. The dismantled material, if any shall be returned to stores
8. Before taking work in hand all instructions of PSPCL amended from time to time must be followed.
9. All clearance shall be maintained as per Electrical Rules/PSPCL Norms while executing the job
10. The instructions issued vide CE/TS memo no. 4587 dated 27.05.2016 shall be complied with.

One copy of technically concurred route plan along with Quality Control

Register No

is enclosed herewith for further necessary action.

DA: As above.

Sr. Xen/TD-II,
PSPCL, Patiala.

For information & necessary action

Length of line 4.917 Ckt. KM, ACSR size 0.2 sq. inch

Sr. Executive Engineer,
T.L. Division, P.S.P.C.L. Patiala

DIVISIONAL FOREST OFFICER
DIVISIONAL FOREST OFFICER
DIVISIONAL FOREST OFFICER
DIVISIONAL FOREST OFFICER
DIVISIONAL FOREST OFFICER
DIVISIONAL FOREST OFFICER
DIVISIONAL FOREST OFFICER
DIVISIONAL FOREST OFFICER
DIVISIONAL FOREST OFFICER
DIVISIONAL FOREST OFFICER

4/3/17