

Full Title of the Project: - Construction of LILO from 400KV D/C Transmission line Lahal to Rajera at Tower no 8 to Pot Head yard for Evacuation of Power of JSW ENERGY (KUTEHR)LTD KUTEHR HEP 3X80 MW Vill. Machhettar Post Chanhota Teh. Bharmour Distt. Chamba. (H.P.)

File no: _____

Date of proposal: _____

CHECK LIST SERIAL NUMBER-31

INFORMATION REGARDING TRANSMISSION LINE

1.	Length and width of Transmission line passing through forest and non-forest area.	Govt./Forest land = 0.887 Km Private land = 0.0 km Total = 0.887 Km Width = 46 Meter
2.	Length of road already existing/constructed out of the total length involved in the project proposal.	-N A-
In case of Transmission line:		
3.	Voltage Level	400 KV
4.	Line Length	0.887 Km
5.	Width of the right of way for transmission line.	46 Mtrs Maximum ROW for 400KV Lines
6.	Number of towers to be erected both in forest and non-forest area.	Forest land = 5 Private land = 0 Total = 5
7.	No. of towers in which both forest and non-forest land required.	Nil
8.	Length of the line passing through Govt. / Forest Area.	0.887 Km.
9.	Length of the line passing through Non-Forest Area.	Nil

For JSW Energy (Kutehr) Limited

(Sanjeev Kumar Mahajan)
Associate Vice President
Sanjeev Kumar Mahajan
Associate Vice President JSW
Energy (Kutehr)Ltd. Village
Machhatter Post chanhouta
Teh Bharmour Distt. Chamba
176309.