



# दिल्ली मेट्रो रेल कॉर्पोरेशन लि० DELHI METRO RAIL CORPORATION LTD.

( भारत सरकार एवं दिल्ली सरकार का संयुक्त उपक्रम )

( A JOINT VENTURE OF GOVERNMENT OF INDIA AND GOVT. OF DELHI )

DMRC/O&M/Tr./PGCIL/T-1 (20)

Date: 10.04.2018

Chief Manager, (Dwarka)

Power Grid Corporation of India Limited

B-9, Qutab Institutional Area Katwaria Sarai

New Delhi - 110016

Sub: Request for issue of NOC for crossing of Blue Line between Dwarka sector 11 & Sector 12  
Metro Station: LILO line of one circuit of 400KV Banmmauli-Jhatikara D/C transmission  
line by POWERGRID.

Ref: (i) PGCIL's letter no. Ref No.-NR1/Dwarka/440KV LILO/Metro crossing proposal/38 dated  
27.02.2018.

(ii) DMRC's letter no. DMRC/O&M/Traction/permission-I/RSJ/T-1 dated 21.03.2018.

(iii) PGCIL's letter no. Ref No.-NR1/Dwarka/440KV LILO/Metro crossing/47 dated  
24.03.2018

(iv) DMRC's letter no. DMRC/O&M/Tr./PGCIL/T-1 dated 28.03.2018.

(v) PGCIL's letter no. Ref No.-NR1/Dwarka/440KV LILO/Metro crossing/49 dated  
05.04.2018

(vi) DMRC's letter no. DMRC/O&M/Tr./PGCIL/T-4 (12) dated 06.04.2018

(vii) PGCIL's letter No. - NR1/Dwarka/400 KV LILO/Metro Crossing/53 dated 10.04.2018

Dear Sir,

This is in reference to the request letter & further confirmations given by PGCIL vide their letters mentioned under ref-(i), (iii), (v) & (vii) against DMRC's letter mentioned under ref-(ii), (iv) & (vi) for issue of NOC for crossing of Blue line metro between Dwarka sector 11 & Sector 12 metro stations.

In view of confirmation given by PGCIL to abide by terms & conditions as mentioned in foregoing correspondences, NOC is being granted by DMRC subject to following conditions /precautions which shall be observed by PGCIL:-

1. Work of PGCIL shall be executed in night during non service hours of DMRC. Formal PTW & Power Block shall be given by DMRC at the written request of engineer/supervisor of PGCIL between 0100 AM to 0400 AM (tentatively). PTW & power block shall be issued subject to its availability.
2. It is understood that PGCIL shall not enter in DMRC's premises. If PGCIL wants to work inside DMRC premises, the same may be clearly indicated in the request for PTW. In this case, PGCIL officials will have to submit indemnity bond in the format of DMRC.
3. While crossing DMRC's line all safety precautions shall be observed by PGCIL and ensure that no materials or conductors etc falls on the DMRC's line.


(मेट्रो भवन, फायर ब्रिगेड लेन, बाराखम्बा रोड, नई दिल्ली-110001)

Metro Bhawan, Fire Brigade Lane, Barakhamba Road, New Delhi-110001

4. PGCIL shall be responsible for any damage or loss to any other civic agency during execution of its work. Proper permission from other concerned civic authorities may be taken by PGCIL with copy to DMRC.
5. PGCIL shall ensure the presence of its site Engineer/Supervisor for taking any instruction from DMRC's supervisor/Engineer during the execution of above work at site.
6. PGCIL shall inform the date and time well in advance to DMRC before execution of work at subject site.
7. Following DMRC's officials shall coordinate in giving PTW to PGCIL officials:
  - i. Sh. Navendu Veer Singh, AM Tr 3 - 9868659699
  - ii. Sh. R.K Mehndiratta, SE/OHE/L-3 - 9971396599

For Power block & PTW, PGCIL shall formally inform the name and contact no. of their responsible officers, control room and PGCIL's supervisor & contractors.

Thanking you,

  
(Subodh Pandey)  
Sr. AGM/Traction