

# UTTAR HARYANA BIJLI VITRAN NIGAM

From

S.E. (OP) Circle  
UHBVN, Sonapat.

To

Xen City Divn.,  
UHBVN, Sonapat

Memo no. Ch. 243 / DRG-74

Dt. 16/12/19

**Sub: Proposal for tapping of 11 KV Express City Independent feeder to release HT BS/DS connection of M/S Jindal Global City Township, Sector-35 Sonapat having connected load 450.000 KW under 'OP' S/Divn. Model Town Sonapat.**

Please refer your office memo no. Ch. 249/DGR-11 dt. 09.12.2019.

As recommend by your office vide memo under reference, the approval is hereby accorded for releasing the subject cited HT BS/DS connection by tapping of 11 KV Express City Independent feeder of M/S Jindal Global City Township from 33 KV S/Stn. Barota in view of S.C. No. U-32/2016, U-10/2017 and U-19/2019. The loading position/max. demand of existing 33/11 KV, 10 MVA T-2 T/F (473 Amps. 90% of rated capacity) installed at 33 KV S/Stn. Barota is recorded 460 amp., hence the existing 10 MVA T/F is capable to take up the load of subject cited consumer, The total load after release of senior pending connections and as well as this prospective consumer will go to the tune of 460 amps. (due to said load already being run on affected power T/F), as such the proposal for providing of 11 KV Independent feeder for this connection is sanctioned subject to the following terms and conditions-

1. The right of way is to be made available for erection of link line and there will be no any type of hindrance at the time erection of line.
2. The meter should be installed on both side and billing should be done as per S/Stn. meters.
3. The tapping of feeder is to be erected overhead on 11 Mtrs. PCC Poles with load matching ACSR conductor/HT XLPE Cable as mention in Sales Circular no. U-32/2016 & U-10/2017.
4. The original cost of the common portion of the independent feeder shall be shared by the new consumer and credit of the same will be given to the original consumers as per clause No. 4.5.3 (VII).
5. Under taking of the consumer on NJS Rs. 10/- to this effect that he will be bound with all the terms and conditions of Sales Circular No. 03/12 & 21/13 and all other instructions issued by the Nigam time to time, may be collected and attached in case file.
6. All other formalities required to be completed for providing 11KV independent feeder/tapping of existing 11KV independent feeder and proper load/CD and estimate is to be sanctioned before starting the work.
7. There should no any type of pending dues against this consumer/applicant.
8. During release of connections it may be insured that the connected load should be within 90% of capacity of affected power T/F.
9. The applicant consented self execution scheme, as such it may be insured that all terms and condition have been implementation meticulously in light of sales circular No. U-17/2018.

The copy of Memorandum, Sketch, format and undertaking etc. as received are returned herewith for doing the needful.

A/As above

S.E.(OP)Circle  
UHBVN, Sonapat.