

**PUNJAB WATER SUPPLY & SEWERAGE BOARD
PLOT NO.1-B, SECTOR 27-A, CHANDIGARH.**

From

Chief Executive Officer,

To

The Chief Engineer (East),
Punjab W/S & Sewerage Board,
Patiala.

No.PWSSB-2016/W/ 1482-1

Dated:- 16-6-2016

Subject: Providing & Laying of Lateral Sewer, Main/ Outfall sewer, RCC Rising Main of various sizes, Construction of Manholes, Construction of Sewage Treatment Plants, RCC Main Pumping Stations, providing & installing of Street lights & all other works contingent thereto including maintenance of the same for construction period & for 10 years after completion at Bassi Pathana town & Sirhind town Distt. Fatehgarh Sahib. (Under BUCIP Scheme).

App. Cost Rs. 133.71 Crore

Reference : Your office letter No. 704 dated 29.04.2016 , on the subject cited above.

Keeping in view the recommendations of High Level Committee Constituted to examine the techno-feasibility of Bid and justification of rates of L-1 bidder and approval accorded by the Committee for Scrutiny and approval of tenders costing more than Rs. 5.00 crore in its meeting held on 17.05.2016 and minutes issued vide PWSSB-2016/D-1/ 10851-60 dated 18.05.2016 (copy enclosed) and as per approval accorded by the Council of Ministers Govt. of Punjab in its meeting held on 01.06.2016 the lowest tender dated 02.03.2016 of M/s GDCL-Krishna JV, B-228, OKHLA, Industrial Area, Phase-I, New Delhi and as amended by the agency vide their letter dated 02.05.2016 (addressed to Major Gen.(Retd.) V.K. Bhatt, Technical Advisor to Hon'ble Chief Minister, Punjab and letter dated 17.05.2016 (addressed to the Chief Executive Officer, PWSS Board, Chandigarh) for the work cited as subject above, the approval to allot the work, is hereby accorded at the following rates, terms and conditions:-

i). RATES:

S. No.	Description	Rates
i)	Providing & Laying of Lateral Sewer, Main/ Outfall sewer, RCC Rising Main of various sizes, Construction of Manholes, Constructions of Sewage Treatment Plants, RCC Main Pumping Stations, providing & installing of Street lights & all other works contingent thereto including maintenance of the same for construction period & for 10 years after completion at Bassi Pathana town & Sirhind town Distt. Fatehgarh Sahib. (Under BUCIP Scheme).	<p>@ 14.99% (Fourteen point Nine Nine percent) above the rates exhibited in the schedule of items of work appended in the approved DNIT.</p> <p><u>For example</u></p> $\left\{ \begin{array}{l} \text{Exhibited} \\ \text{complete rate of} \\ \text{schedule of} \\ \text{items of work} \end{array} \right\} \times \frac{(100+14.99)}{100}$

ii)	Average Daily Guaranteed Power Consumption in KVAH.	
iii)	(i) For 5 MLD STP Sirhind	1340 KVAH
	(ii) For 4 MLD STP Sirhind	970 KVAH
	(iii) For 2 MLD STP Sirhind	650 KVAH
	(iv) For 3 MLD STP Bassi Pathana	870 KVAH
	(v) For 200 KLD STP Bassi Pathana	202 KVAH

(ii) TIME LIMIT:

Sr. No.	Description	Completion Time
1	Providing & Laying of Lateral Sewer, Main/ Outfall sewer, RCC Rising Main of various sizes, Construction of Manholes, Construction of Sewage Treatment Plants, RCC Main Pumping Stations, providing & installing of Street lights & all other works contingent thereto including maintenance of the same for construction period & for 10 years after completion at Bassi Pathana town & Sirhind town Distt. Fatehgarh Sahib. (Under BUCIP Scheme).	18 (Eighteen) Months.
2	Operation and Maintenance period for existing and proposed services.	Construction period +120 months.
3	Operation and Maintenance period for proposed services.	120 Months.

(iii) M/s. SFC Environmental Technologies Pvt. Ltd., Navi Mumbai is technology provider for STP.

(iv) The scope, specifications and makes shall be as per approved DNIT.

All other terms & conditions shall be as per approved DNIT. However, the approval of Engineer-in-charge /Competent Authority in respect of items about which DNIT is silent will be required.

The following tender documents are returned herewith in original; -

1. 3 No. tenders in original
2. ✓ Comparative statement.
3. ✓ Firm's letter dated 02.05.2016 and 17.05.2016
4. ✓ Copy of Minutes of meeting dated 17.05.2016

Note:-i) Before execution of work, compliance of the points covered in the Technical Note in the DNIT be ensured.

ii) The concerned SE/EE should ensure quality of work by regular inspections/checking at site.

(iii) Time frame for completion of sewerage works etc. within time limit be finalized/conveyed to the agency.

(iv) Inadvertent error or omissions, if any, be informed & get rectified from the this office before issue of allotment of letter to the agency.

DA/ As above.

(Sr. No.1 to 4)

Endst.No.PWSSB-2016/W/

A copy of above is forwarded to General Manager (Finance) in the Head Office for information and necessary action.

Director (Planning & Design)
For Chief Executive Officer.

Dated 15/6/16 16-6-2016

Director (Planning & Design)
For Chief Executive Officer.

①

ਪਿਛਲੇ ਪੰਨੇ ਤੋਂ:

ਪੰਜਾਬ ਵਾਟਰ ਸਪਲਾਈ ਅਤੇ ਸੀਵਰੇਜ਼ ਹਲਕਾ, ਪਟਿਆਲਾ

ਪਿੱਠ ਅੰਕਣ ਨੰ: ਪਵਸਸਹਪ/2016/ 3307

ਮਿਤੀ:- 27/6/16

ਉਪਰੋਕਤ ਦਾ ਉਤਾਰਾ ਕਾਰਜਕਾਰੀ ਇੰਜੀਨੀਅਰ, ਪੰਜਾਬ ਵਾਟਰ ਸਪਲਾਈ ਅਤੇ ਸੀਵਰੇਜ਼

ਮਿਡਲ ਨੰ: 2, ਪਟਿਆਲਾ ਨੂੰ ਸੂਚਨਾ ਅਤੇ ਅਗਲੇਰੀ ਜ਼ਰੂਰੀ ਕਾਰਵਾਈ ਹਿੱਤ ਭੇਜਿਆ ਜਾਂਦਾ ਹੈ।

ਨੱਥੀ/- ਟੈਂਡਰ ਕੇਸ ਅਸਲ ਰੂਪ ਵਿਚ।

ਨਿਗਰਾਨ ਇੰਜੀਨੀਅਰ

ਪਵਸਸ ਹਲਕਾ, ਪਟਿਆਲਾ।

Received

27/6/16