


TOWER SPECIFICATION OF 132 kV SANKARDEVNAGAR - LUMDING
TRANSMISSION LINE FOR 220 kV GRID SUB-STATION, AEGCL, SAMAGURI

S.N	TOWER SPECIFICATION	
1	Tower Height	27.65 meter
2	Minimum Ground Clearance	6.1 meter
3	Right of Way	27 meter


Assistant General Manager
220 KV Grid Sub-Station
AEGCL Samaguri