

**Registered/AD**

101 Road Constructions Coy (GREF)

Pin : 930101

C/o 56 APO

2030/43/E2

10 Mar 2017

**Er. A.K. Malhotra**

Executive Engineer (C&M, TCC-IX)

R.R.V.P.N. Ltd

KV GSS Premise, Sagar Road

Bikaner, Rajasthan

**GRANTING PERMISSION FOR ROAD CROSSING FOR LAYING OF 132 KV S/C NOKHADAIYA-KHAJUWALA TRANSMISSION LINE OF DISTRICT BIKANER IN RAJASTHAN STATE AND RESTORATION/REPAIR WORKS UNDER TAKING THERE OF**

1. Reference your letter No. RRVPNL/XEN (C&M-TCC IX)/BKN/Tech./Estt/D 1163 dated 14 Jan 2016, "undertaking letter No. 1426 dated 14 Mar 2016" and letter No. RRVPNL/Executive Engineer (T&C)/Bikaner/Tech./Estt/D.1329 dated 09 Mar 2017 for permission for road crossing for laying of 132 KV S/C Nokhadaiya-Khajuwala transmission line of District Bikaner.
2. In this connection also refer this office letter No. 2030/19/E2 dated 16 Mar 2016.
2. This permission for road crossing for laying of 132 KV S/C Nokhadaiya-Khajuwala transmission line of District Bikaner is given on the basis of HQ CE (P) Chetak letter No. 20000-A/Gen/77/E2 Wks dated 15 Jan 2016.
3. This permission of road crossing for laying of 132 KV S/C Nokhadaiya-Khajuwala transmission line as accorded will become null & void if, the terms & conditions of the "Undertaking and Joint Inspection Report" as given below are not followed by the Executive engineer (C&M,TCC-IX) RRVPN Ltd, Bikaner.
  - (a) That the traffic will not be affected during execution of the work.
  - (b) Provide suitable diversion along with adequate safety measure for traffic during execution of work.
  - (c) Erection of tower is far away from the Right of Way and it will not provide any obstacle in the extension of road in future if required.
  - (d) No claim will be raised by R.R.V.P.N. Ltd Bikaner, Rajasthan at future date in case the Transmission line are to be disturbed/dismantled by BRO for improvement of road or road or for any other technical/administrative initiatives reasons.

Contd- P/2

(e) All restoration work if occurred will be carried out by R.R.V.P.N. Ltd Bikaner, Rajasthan within 10 days with their own resources to make roads its original shape.

(f) Maintenance and repair of line in future after laying of transmission line, if at all required shall be done by RRVPN Ltd, Bikaner.

(g) "The vertical clearance of transmission line from the road surface to fulfill requirement of ARMY or any other agency in future" will be carried out by RRVPN Ltd, Bikaner without any compensation/claim from BRO.

4. This permission of road crossing for laying of 132 KV S/C Nokhadaiya-Khajuwala transmission line is granted with condition that "Payment to the contractor/subcontractor" by R.R.V.P.N. Ltd will be cleared only after clearance from BRO(OC/ Offg OC 101 RCC/ CE(P) Chetak).

  
**(Prasad Sawant)**  
Major  
Officer Commanding

**Copy to -**

HQ CE(P) Chetak  
C/o 56 APO

HQ 49 BRTF  
C/o 56 APO

} For info pl.

Shri B R Sinwer, JE(Civ),  
Offg OIC

Shri Kailash Chand,  
AE(Civ), OIC

- } 1. For info & ensure action on ground as per above please.  
2. Also ensure to submit confirmation report to this HQ.