

PSPCL

Power Corporation Limited

(Regd. Office: PSEB Head Office, The Mall, Patiala)
Office of Chief Engineer/Transmission System
S-1 Shakti Vihar, Patiala.

Endst. No. 85-TLW-282
Date: 4/10/17

Copy of the route plan forwarded to
PSPCL, Patiala for further necessary action

Dr. Chief Engineer
TL Circle, PSPCL Patiala
Memo No. 100/17

/TSR-414

Dr. Chief Engineer
PSPCL, Patiala
Date: 28/9/17

Subject:

Ref:

Proposed Route plan of 66 KV SC line on DC towers from 66 KV S/s
Ramuwala - 66 KV S/s Charik.
Please refer to your office endst no. 3700 dtd. 03.08.17 and Endst. no.
3987 dtd. 01.09.2017.

Subject cited route plan submitted vide your letter under reference has been
technically concurred with corrections/comments on drawing subject to the following
conditions

1. First and last tower of the route shall be adjusted as per Gantry location at the
G/s Sub-Station
2. The technical concurrence is being given strictly as per recommendations of
Dy. CE/TL circle Patiala & ASE/TL Div. Bathinda purely on technical basis
3. The route has been technically concurred in view of certificate that route is
shortest technical possible
4. Approval of authorized person of PSTCL should be obtained for crossing of
400 KV TWS NKS line with subject cited line at TL no 4 - 5 before taking
work in hand
5. Approval of authorized person of PSTCL should be obtained for crossing of
400 KV TWS NKS line with subject cited line at TL no 16 - 17 before taking
work in hand
6. Approval of authorized person of PGCIL should be obtained for crossing of
Moga - Bhiwadi line with subject cited line with at TL no.7 - 8 at your level
before taking work in hand
7. The dismantled material if any shall be returned to stores
8. Before taking work in hand all instructions of PSPCL amended from time to
time must be followed.
9. All clearance shall be maintained as per Electrical Rules/PSPCL Norms while
executing the job
10. The instructions issued vide GETS memo-no.4587 dated 27.05.2016 shall be
complied with

Register No
DA as above

[Signature]

Asstt. Executive Engineer
T. L. Sub Division, PSPCL
SANGRUR H.Q. BARNALA
Mr. Xen/TD-II
PSPCL, Patiala.

For information & necessary action.