

GOVERNMENT OF ARUNACHAL PRADESH  
DEPARTMENT OF POWER :: CIVIL SECRETARIAT  
ITANAGAR.

No.PWRS/W-1989/2009/Vol-II/1056-51 Dated Itanagar, the 3rd March, 2014.

To, ✓

M/s Sew New Melling Power Corporation Ltd.  
6-3-871, 'SNEHALATA', Greenlands Road,  
Begumpet, Hyderabad - 500 016,  
Andhra Pradesh.

Sub: **Confirmation of TWL level in respect of New Melling HEP and FRL of Magochu HEP.**

Ref: SEL/NMHEP/T/2013/69 dated 04/01/2014.

Dear Sir(s),

With reference to your letter No.SEL/NM HEP/T/2014/72 dated 04/02/2014 the change of TWL from 2520m to 2508m and change of minimum TWL from 2517.78m to 2506.24 has been approved.

Therefore, the levels of New Melling HEP are as given below:

1. FRL 2730m as per MoA.
2. Normal TWL 2508m.
3. Minimum TWL 2506.24m.

This is for your information and needful action please.

Sri Rameshkrishna Parane haws  
α

Yours faithfully,

*[Signature]*  
03/03/2014

(Tayi Taggu)

Under Secretary (Power)  
Govt. of Arunachal Pradesh  
Itanagar.


No.PWRS/ W-1989/2009/Vol-II

Dated Itanagar, the March, 2014.

Copy to:

The Chief Engineer (Monitoring), Department of Hydro Power Development,  
Itanagar for Information please.

*[Signature]*  
Jayaprakash N.  
Business Associate



(Tayi Taggu)  
Under Secretary (Power)  
Govt. of Arunachal Pradesh  
Itanagar.