



DETAIL OF DISPENSOR				
Sr.No.	TYPE OF DISPENSOR			
1	1 MPD MS/HSD			
2	1 MPD MS/HSD			

DETAIL OF TANKS					
Sr.No.	PRODUCT	CAPACITY	DIA Ø	LENGTH	TYPE OF TANKS
1	MS	15KL	2.01Ø	5.00M	E-PIT
2	HSD	20KL	2.01Ø	6.75M	E-PIT

SITE INFORMATION								
PLOT AREA	1328.99 SqmL							
KHASRA NO.	269							
LOCATION	BELHARI							
PARGANA	GONDA							
TEHSIL	GONDA							
POST OFFICE	DHANEYPUR							
POLICE STATION	DHANEYPUR							
RAILWAY STATION	GONDA							
DISTRICT	GONDA							
STATE	UTTAR PRADESH							
PIN CODE	217 602							
NEAR KM STONE NO.	19	REVISION	DATE	ZONE OR	BRIEF RECORD	INITIALS		
ROAD NO.	M.D.R. - 18E	DRG. NO.		PART				



1. V = VENT PIPES 4M HIGH AND END COVERED WITH 2 LAYERS OF BRASS WIRE GAUGE 11 MESH PER LINEAR CENTIMETER.
2. F = FILL POINTS FITTED WITH CAMLOCK COUPLING AND AIR TIGHT THREADED BRASS CAP FOR DECANTING FROM TANK LORRY.
3. D = DIP PIPES WITH CAP ASSEMBLY.
4. ALL ELECTRICAL FITTINGS ARE FLAME PROOF CONFORMING TO IS :2148
5. ALL DOORS OF BUILDING TO BE OPENED OUTWARDLY.
6. NO SEWER OR SURFACE DRAIN WITHIN 6M OF THE U/G TANK & D/U.
7. PREMISES TO BE USED FOR ONLY STORAGE OF PETROLEUM PRODUCTS.
8. TANKS ARE PAINTED WITH TWO LAYERS OF HOT BITUMEN OVER TWO COATS OF RED LEAD PRIMER TO PROTECT AGAINST CORROSION.
9. FABRICATION DESIGN OF UNDER GROUND STORAGE TANK ARE CONFORMING TO I.S.: 10987 : 1998 AS PER C.C.O.E. NAGPUR ORDER NO. G-40 (SC) P/MISC 94 DATED-24.02.99.
10. ALL DIMENSIONS ARE IN MTR. UNLESS OTHERWISE NOTED.
11. S.B. SAND BUCKET 10 NO'S OR AS PER EXPLOSIVE RULES.
12. F.E. FIRE EXTINGUISHER, 10 NO'S OR AS PER EXPLOSIVE RULES.
13. TANK SHOULD BE GIVEN HYDROUC PRESSURE TEST PRIOR TO INSTALLATION AND BEFORE ANY PROTECTIVE COATING AS APPLIED.
14. THE TEST SHOULD BE MAINTAINED AT A CONTROLLED PRESSURE OF 0.36KG/SQ.CM. FOR 2 HOURS.
15. DIP ROD SUPPLIED WITH THE TANK FOR THIS TYPE OF INSTALLATION SHOULD BE 3280 LONG INSTEAD OF STANDARD 2350MM.
16. INSTALLATION THICKNESS OF SHELL PLATES AND END PLATE OF TANKS:
20KLSHELL-6MM
END - 8MM
17. TANKS CONFORMS TO 124.125 & 131 OF THE PETROLEUM RULE-2002
18. ALL LIGHT POLES ARE FITTED AS PER APPROVAL OF CCE NAGPUR vide LETTER NO. PL-III(MB) DATED:26.11.1963.
19. NATURAL DRAIN SLOPE FROM THE EDGE OF METALLED ROAD TO CULVERT ON APPROACHES WILL BE MAINTAINED FREE FLOW OF WATER TOWARDS DRAIN.
20. SITE MEETS APPLICABLE IRC.1983 NORMS WITH LATEST AMENDMENTS.
21. EV = EXTENDED VENT POINT
E = EXTENDED FILL POINTS.
22. THE PROPOSED SITE IS FREE FROM ANY TYPE OF LITIGATION AND NO CASE IS PENDING IN ANY COURT OF LAW.
23. NO ELECTRICAL LINE PASSES OVER THE R/O PREMISES
24. PROPOSED AND EXISTING WORK SHOWN IN SPECIFIC COLOUR
25. HOARDING BOARD WILL BE NOT USED FLEX MATERIAL

		भारत पेट्रोलियम कॉर्पोरेशन लिमिटेड BHARAT PETROLEUM CORPORATION LTD. (MARKETING - DIVISION)					
Subject:- Layout Plan of a Retail Outlet							
Gonda - Utraula Road ,At -Village - Belhari - Gonda ,District - Gonda ,Near Km.Stone No.19 (M.D.R. - 18 E)				06.03.17	BPCL/19G/2017		
				DATE	DRAWING NO.		
				NUMBERS CROSSED OUT ARE SUPERSEDED DRAWING NO.			
Gonda (U.P.)		At.- Village - Belhari					
03.2017	CHIEF ENGINEER		DIV./MANAGER		BPCL/19G/2017 DRAWING NO.		
200							
Arvind Kumar	TRACED	CHECKED					
					 AMI VARORA Dy. Manager Construction (Retail) Bharat Petroleum Corporation Limited Gurgaon		