	<b>HIMACHAL PRADESH STATE ELECTRICITY BOARD LIMITED</b> <i>(A State Govt. undertaking)</i>	
	Registered Office :	Vidyut Bhawan, HPSEBL, Shimla-171004 (H.P.)
	Number (CIN) :	U40109HP2009SGC031255
	GST No. :	02AACCI14894EHZB
	Telephone No. :	0177-2803600, 2801675 (Office), 2658984 (Fax)
Website Address :	www.hpsebl.com	
Email :	smt@hpsebl.in & director@hpsebl.in	

HPSEBL/SED-DB-33/2022-23- 9069-70

Dated: 28.11.2022.

To

✓ The Addl. General Manager (Sewerage),  
Shimla Jal Prabandhan Nigam Ltd.,  
US Club, Shimla, Himachal Pradesh.


**Subject: -** Diversion of 0.4122 ha. of forest land in favour of Shimla Jal Prabandhan Nigam Limited, US Club Shimla-1 Himachal Pradesh, for the construction of Sewerage Treatment Plant 3.10MLD at Ashawani Khad within the Jurisdiction of Shimla Forest Division, Distt. Shimla, Himachal Pradesh (Online Proposal No. FP/ HP/ Other/ 149118/2021).

Sir,

As reported by the Assistant Engineer, ESD, HPSEBL, Junga vide his office letter No. JESD/W-3/2022-23-562 dated 26.11.2022 that 11kV HT line from Ashwani Khad to Bhad 2<sup>nd</sup> is passing over the proposed plot of Sewerage Treatment Plant (STP). However, it was appraised by the concerned JE, Jal Prabandhan Nigam Ltd. the installation of Sewerage Treatment Plant will not affect the clearance of 11kV HT line. However, if required the SJPNL will pay the mandatory charges & provide the Right of Way for shifting of existing HT line.

However, the conditional N.o.C may be provided to the applicant that applicant shall be Maintained adequate distance from the existing 11kV HT Line as per Regulation 2010 i.e Minimum Horizontal clearance = 1.219 meter and vertical clearance = 3.658 meter otherwise applicant may provide "Right of way" along with sufficient required expenditure to shift the HT Line to suitable place.

Yours Sincerely,

  
(Er. Pardeep Singh Sidholi)  
Sr. Executive Engineer  
Shimla Electrical Division No.-I  
HPSEB Ltd, Kasumpti, Shimla-9

Copy to the Assistant Engineer ESD, HPSEB Ltd, Junga with reference to his office mentioned above for information please.

—sd—

Sr. Executive Engineer,  
Shimla Electrical Division No.-I,  
HPSEB Ltd, Kasumpti, Shimla-9.