

**REF: NBBG-SPTL-Forest-17****Date: 25.04.2022**

To,

The Nodal Officer (FC Act)  
Office of the Principal Chief Conservator of Forest and HoFF  
Panjabari, Guwahati – 781037, Assam

Sub: - Construction of 400 kV D/C Bongaigaon-Nangalbibra Transmission line: ***compliance of the online observation dated 19.04.2022.***

Reference: - Online observation dated 19.04.2022 in the proposal No. FP/AS/TRANS/152968/2022.

Dear Sir,

With reference to your online observation dated 19.04.2022, please find below the pointwise response of the queries raised by your good office:


| S. No.           | Query  | Response   |
|------------------|--|--|
| <b>Goalpara</b>  |  |  |
| C-(ii)<br>(b)    | After careful examination of the KML file and the Joint Verification report of the Goalpara Division it seems that some non-forest area has been included in the patch with respect to Sagunbasi RF. Please rectify the anomalies and upload the KML file accordingly.   | The disparity has been rectified in the maps and uploaded accordingly. |
| C-(iii)          | After careful examination of the uploaded SOI (1:50000 scale) toposheet map it is found that some of the DGPS coordinate readings do not fall exactly in the proposed forest land to be diverted. Further, after examining the Joint Verification report of the Goalpara Division it seems that some non-forest area has been included in the patch with respect to Sagunbasi RF. Please rectify the anomalies and upload the map accordingly. | The disparity has been rectified in the maps and uploaded accordingly. |
| C-(iv)-          | After careful examination of the uploaded Geo-referenced map it is found that some of the DGPS coordinate readings do not fall exactly in the proposed forest land to be diverted. Further, after examining the Joint Verification report of the Goalpara Division it seems that some non-forest area has been included in the patch with respect to Sagunbasi RF. Please rectify the anomalies and upload the map accordingly.                | The disparity has been rectified in the maps and uploaded accordingly. |
| <b>Haltugaon</b> |  |  |
| C-(iii)          | After careful examination of the uploaded SOI (1:50000 scale) toposheet map it is found that some of the DGPS coordinate readings do not fall exactly in the proposed forest land to be diverted. Please rectify the anomalies and upload the map accordingly.   | The disparity has been rectified in the maps and uploaded accordingly. |

|                                |   |   |
|--------------------------------|---|---|
| C-(iv)-                        | After careful examination of the uploaded Geo-referenced map it is found that some of the DGPS coordinate readings do not fall exactly in the proposed forest land to be diverted. Please rectify the anomalies and upload the map accordingly. | The disparity has been rectified in the maps and uploaded accordingly.  |
| <b>Additional Information:</b> |   |   |
| 1.                             | Please upload an intimation letter stating the reason for change of area of the proposed land to be diverted.   | The intimation letter stating the reason for change of forest area of the proposed for diversion is uploaded in the additional document section captioning <b><i>“Intimation letter for Change in Forest Area proposed for diversion”</i></b> . |
| 2.                             | Please upload the document stating the minimum clearance above the ground from the lowest conductor of the transmission tower.  | The documents having the required details has been uploaded in the additional document section captioning <b><i>“Details of the Minimum ground clearance of the lowest conductors in forest area”</i></b> .                                     |

In view of the above, you are requested to kindly accept the proposal so that it can be processed further.

Thanking You,

For Nangalbibra-Bongaigaon Transmission Ltd



Authorized Signatory,

Bhaskar Singh Rawat

Chief Manager

Mob: +91 8260154039

Email: [bhaskar.rawat@sterlite.com](mailto:bhaskar.rawat@sterlite.com)