

Minimum Ground Clearance of Each Span in Forest Area at Null Point including 6 meters Additional Height					
Name of Segment	S. No.	Towers No.	Minimum Ground Clearance (m)	DGPS Co-ordinates	
				Longitude	Lalitude
Satbhendi Reserve Forest	1	Entry		90°22'23.32"	26°27'44.18"
			16.13		
	2	Tower-01		90°22'24.28"	26°27'44.28"
			22.50		
	3	Exit		90°22'27.2"	26°27'46.47"

Minimum Ground Clearance of Each Span in Forest Area at Null Point including 6 meters Additional Height					
Name of Segment	S. No.	Towers No.	Minimum Ground Clearance (m)	DGPS Co-ordinates	
				Longitude	Lalitude
Bhairab PRF	1	Entry		90°29'8.51"	26°17'36.66"
			33.89		
	2	Tower-48		90°29'10.43"	26°17'35.74"
			17.53		
	3	Tower-49		90°29'16.99"	26°17'26.66"
			33.27		
	4	Exit		90°29'19.69"	26°17'19.3"
	5	Entry		90°29'20.85"	26°17'16.16"
			19.63		
	6	Tower-50		90°29'23.18"	26°17'9.84"
			16.81		
	7	Exit		90°29'26.21"	26°17'1.7"
	8	Entry		90°29'29.68"	26°16'52.56"
			23.33		
	9	Tower-50/1		90°29'32.91"	26°16'43.98"
			15.13		
	10	Tower-51		90°29'36.29"	26°16'38.37"
			17.48		
	11	Tower-51/1		90°30'1.84"	26°16'22.63"
			22.75		
	12	Exit		90°30'11.83"	26°16'16.47"
	13	Entry		90°30'17.99"	26°16'12.68"
			15.44		
	14	Tower-51/2		90°30'30.33"	26°16'5.08"
			25.49		
	15	Tower-51/3		90°30'51.07"	26°15'52.29"
			16.67		
	16	Exit		90°30'59.04"	26°15'47.37"

Minimum Ground Clearance of Each Span in Forest Area at Null Point including 6 meters Additional Height					
Name of Segment	S. No.	Towers No.	Minimum Ground Clearance (m)	DGPS Co-ordinates	
				Longitude	Lalitude
Panchratna Hill R.F	1	Entry		90°33'45.87"	26°11'45.56"
			32.59		
	2	Tower-67/3		90°33'45.93"	26°11'39.4"
			20.72		
	3	Tower-67/4		90°33'46.13"	26°11'29.51"
			19.10		
	4	Tower-68		90°33'46.22"	26°11'25.09"
			17.70		
	5	Tower-68/1		90°33'49.86"	26°11'21.81"
			16.65		
	6	Tower-68/2		90°34'2.89"	26°11'10.04"
			22.80		
	7	Tower-68/3		90°34'8.15"	26°11'5.3"
			18.89		
	8	Tower-68/4		90°34'17.65"	26°10'56.71"
			26.50		
	9	Exit		90°34'27.47"	26°10'47.84"
Bagulamari P.R.F	10	Entry		90°34'26.28"	26°9'42.92"
			17.33		
	11	Tower-70/3		90°34'24.21"	26°9'35.31"
			15.15		
	12	Tower-70/4		90°34'20.94"	26°9'23.4"
			16.64		
	13	Tower-71		90°34'18.57"	26°9'14.77"
			21.18		
	14	Tower-72		90°34'17.67"	26°9'6.74"
			15.50		
	15	Tower-72/1		90°34'17.79"	26°8'52.18"
			15.30		
	16	Tower-72/2		90°34'17.89"	26°8'40.1"
			15.44		
	17	Tower-72/3		90°34'17.99"	26°8'27.82"
			15.16		
	18	Tower-72/4		90°34'18.1"	26°8'14.93"
			15.16		
	19	Tower-72/5		90°34'18.2"	26°8'3.27"
			15.70		
	20	Tower-72/6		90°34'18.3"	26°7'51.77"
			15.70		
	21	Exit		90°34'18.33"	26°7'47.62"
	22	Entry		90°34'7.61"	26°6'29.46"
			37.32		

Sagunbasi R.F	23	Tower-77		90°34'10.84"	26° 6'27.09"
			24.60		
	24	Tower-78		90°34'12.45"	26° 6'19.16"
			19.28		
	25	Exit		90°34'14.47"	26°6'18.04"
Rakhyashini P.R.F	26	Entry		90°34'14.81"	26°6'17.84"
			19.92		
	27	Tower-79		90°34'17.69"	26°6'16.21"
			22.10		
	28	Tower-80		90°34'17.45"	26°6'8.27"
			32.22		
	29	Tower-81		90°34'22.21"	26°6'5.44"
			23.89		
	30	Exit		90°34'27.81"	26°5'53.8"
Zangrajangsa R.F	31	Entry		90°34'23.05"	25°58'21.04"
			18.90		
	32	Tower-93		90°34'25.08"	25°58'20.11"
			15.75		
	33	Tower-93/1		90°34'27.76"	25°58'7.34"
			17.50		
	34	Tower-93/2		90°34'32.17"	25°57'53.45"
			20.46		
	35	Tower-93/3		90°34'34.3"	25°57'46.75"
			15.20		
	36	Tower-93/4		90°34'35.61"	25°57'42.61"
			20.68		
	37	Tower-93/5		90°34'40.65"	25°57'26.74"
			16.89		
	38	Exit		90°34'42.8"	25°57'20.11"

