



HARYANA VIDYUT PRASARAN NIGAM LTD.  
CE/ Planning, Shakti Bhawan, Sector-6, Panchkula-134109  
Fax 0172-2584415, Phone 0172-2584338

To  
Diary No. 7080 NCR/PLG/GGN. SE/Plg., Area Pl., NCR,  
Dated 8.8.2016 Supdt./PA/Others  
The Chief General Manager/ PD&C,  
UHBVNL, Panchkula.

Director (Technical)  
27/7/16

Dated: 27.07.2016

Memo No. R- 1421/ Ch-27/NCR/KNL-823

Subject:- Creation of 132 kV substation in Bapoli area in Samalkha Constituency, District Panipat (Code 10101 dated 10/05/2015) covered under CM's announcements: Change of site now creation of 132 kV substation at Noorpur Muglan.

In view of non-availability of land in Noorpur Muglan and alternate site offered by Gram Panchayat of village Pasina khurd for creation of 132 kV substation, the revised proposal for Creation of 132 kV substation in Bapoli area in Samalkha Constituency, District Panipat (Code 10101 dated 10/05/2015) covered under CM's announcements was submitted for consideration and approval of WTDs of HVPN.

The proposal has been considered and decided by WTDs of HVPNL as under:-

Sr.No	Description	Code
1	Cancellation of Following works at Sr.No. 1, 2 & 7 approved vide CE/Planning No R No1393/Ch-24/NCR/KNL-823 dated 02.03.2016 : a) Creation of 132 kV Substation. Noorpur Muglan with installation of 2x40/50 MVA, 132/33 kV transformer along with 2 x 0.2 MVA 33/0.4 kV transformer for auxiliary supply to be fed from LILO of 132 kV S/C Beholi - Chhajpur line to feed the load of 33kV substation Noorpur Muglan (20MVA), Rishalu (20MVA) & new 33kV substations Pasina Kalan (20MVA), Sector-25 Part-I (25MVA) & Simla Gujran (20MVA) with future provision of four 132kV line bays and one transformer bay . ( Code No 1N2917*) b) Creation of LILO of 132 kV S/C Beholi - Chhajpur line with 0.4 sq. inch ACSR conductor (approximate 2 KM) (code no 1L2918*). c) To concur the shifting of 33 kV S/Stn. Noorpur Muglan (20 MVA) & 33 kV S/Stn. Rishalu (20 MVA) from 132 kV S/Stn. Beholi to proposed 132 kV S/Stn. Noorpur Muglan by UHBVN.	1N2917A 1L2918A
2	Creation of 132 kV Substation. Pasina Khurd with installation of 2x40/50 MVA, 132/33 kV transformer along with 2 x 0.2 MVA 33/0.4 kV transformer for auxiliary supply to be fed from LILO of 132 kV S/C Beholi - Chhajpur line to feed the load of 33kV substation Noorpur Muglan (20MVA), Rishalu (20MVA) & new 33kV substations Pasina Kalan (20MVA), Sector-25 Part-I (25MVA) & Simla Gujran (20MVA) with future provision of two 132kV line bays and one 132/33kV transformer bay with back to back arrangement if required.	1N3067*
3	Creation of LILO of 132 kV S/C Beholi - Chhajpur line with 0.4 sq. inch ACSR conductor (approximate 2 KM) at 132 kV substation Pasinakhurd	1L3068*





# HARYANA VIDYUT PRASARAN NIGAM LTD.

Corporate Identity Number: U40101HR1997SGC033683

CE/ Planning, Shakti Bhawan, Sector-6, Panchkula-134109

Fax 0172-2584415, Phone 0172-2584338

To

The Chief General Manager/ PD&C,  
UHBVNL, Panchkula.

Memo. No. R- 1393/Ch-24/NCR/KNL-823

Dated: 02.03.2016

**Subject: Proposal for creation of 132 kV substation Noorpur Muglan in Samalakha Constituency District Panipat (CM Announcement No. 10101).**

This is with reference to the proposal sent vide your office Memo no. Ch-02/Plg-629/PNP dated 17.02.2016 for creation of 132 kV substation Noorpur Muglan in Samalakha constituency District Panipat (CM Announcement No. 10101).

The proposal has been considered and decided by WTDs of HVPNL as under:-

Sr. No	Description	Code
1	Creation of 132 kV Substation. Noorpur Muglan with installation of 2x40/50 MVA, 132/33 kV transformer along with 2 x 0.2 MVA 33/0.4 kV transformer for auxiliary supply to be fed from LILO of 132 kV S/C Beholi - Chhajpur line to feed the load of 33kV substation Noorpur Muglan (20MVA), Rishalu (20MVA) & new 33kV substations Pasina Kalan (20MVA), Sector-25 Part-I (25MVA) & Simla Gujran (20MVA) with future provision of 4(four) 132kV line bays and one transformer bay.	1N2917*
2	Creation of LILO of 132 kV S/C Beholi - Chhajpur line with 0.4 sq. inch ACSR conductor (approximate 2KM).	1L2918*
3	Stringing of 2 <sup>nd</sup> circuit of 132 kV Beholi - Chhajpur S/C line on D/C towers with 0.4 sq" ACSR conductor.	1L2919*
4	Creation of one no. bay at 220 kV substation Chhajpur to accommodate the stringing of 2 <sup>nd</sup> circuit of 132 kV Beholi - Chhajpur line.	1B2920*
5	Creation of one no. bay at 132kV substation Beholi to accommodate the stringing of 2 <sup>nd</sup> circuit of 132 kV Beholi - Chhajpur line.	1B2921*
6	To concur creation of new 33kV Substation Pasina Kalan (20MVA), Sector-25 Part-1 (25MVA), Simla Gujran (20MVA) by UHBVNL.	
7	To concur the shifting of 33 kV S/Stn.Noorpur Muglan (20 MVA) & 33 kV S/Stn.Risalu (20 MVA) from 132 kV S/Stn.Beholi to proposed 132 kV S/Stn.Noorpur Muglan by UHBVN.	
8	Cancellation of creation of 1 No. 33 kV bay at 132 kV S/Stn.Beholi to feed new 33 kV S/stn.Risalu in FY 2017-18 approved vide CE/Planning office memo No. R-1325/Ch-23/NCR/KNL -807 dated 15.01.2015 at Sr. No.24 (Code No. 3B2751*).	3B2751A
9	To concur cancellation of allocation of 1 No. 33 kV bay at 132 kV S/Stn.Beholi to feed 33 kV S/stn.Noorpur Muglan approved vide CE/Planning office memo No. R-1111/Ch-6/NCR/KNL -450 dated 14.05.2013 for future allocation.	
10	To include the works at Sr.1 to 5 in the works of HVPNL for completion in FY 2017-18 after ensuring financial tie up and HERC approval.	

This issues with the approval of WTDs HVPNL on NP-14 & 15 of file no. NCR/KNL-823.

*[Signature]*

Planning.