



भारत सरकार / Government of India
विद्युत मंत्रालय / Ministry of Power
केन्द्रीय विद्युत प्राधिकरण / Central Electricity Authority
प्रणाली योजना एवं परियोजना मूल्यांकन प्रभाग
System Planning & Project Appraisal Division
सेवा भवन आरण केण पुरम नई दिल्ली-110066
Sewa Bhawan, R. K. Puram, New Delhi-110066 [ISO: 9001:2008]
वेबसाइट / Website: www.cea.nic.in



F.No 26/3/2015/ SP & PA/1005-56

Dated: 24 April, 2015.

To,
Vice President & Project In – charge,
Power Finance Corporation Consulting Limited
First Floor, "Urjanidhi", 1 Barakhamba Lane
Connaught Place, New Delhi - 110001

Subject: Prior approval of the Government under section 68 of the Electricity Act, 2003 for the transmission project – "System Strengthening for IPPs in Chhattisgarh and other generation projects in Western Region".

Reference: PFC consulting Limited letter no. 03/ITPs/14-15/CWRTL dated 05.02.2015


Sir,

This has reference to PFC Consulting Limited (Bid Process Coordinator) letter dated 05.02.2015, seeking prior approval of Government under section 68(1) of Electricity Act, 2003 in favour of M/s **Chhattisgarh – WR Transmission Limited** for implementation of "System Strengthening for IPPs in Chhattisgarh and other generation projects in Western Region" with the following scope of works:

S.No.	Transmission scheme
1.	400kV interconnection at Gwalior 765/400kV S/S
i)	Gwalior – Morena 400kV D/C (quad) line.
ii)	Establishment of 2X315MVA, 400/220kV S/S at Morena 400kV: <ul style="list-style-type: none"> Line bays – 2nos. ICT – 2X315MVA, 400/220kV ICT bays – 2nos. Bus reactor – 1X125MVAR Space for 400kV bays – 4nos 220kV: <ul style="list-style-type: none"> Line bays – 4nos. ICT bays – 2 nos. Space for 220kv bays – 4 nos
2.	Additional evacuation line from Vindhyachal – IV & V STPP (3X500MW)

i)	Vindhyachal – IV & V STPP – Vindhyachal pool 400kV D/C (Quad) 2 nd line
ii)	2nos 400kV line bays at Vindhyachal – V STPP switch yard.
3.	Additional system strengthening scheme for Chhattisgarh IPPs (Part -A)
i)	Sasan UMPP – Vindhyachal pool station 765kV S/C line.
ii)	1no. of 765kV line bay at Sasan UMPP of M/s SPL, Reliance.
iii)	LILO of one circuit of Aurangabad – Padghe 765kV D/C line at Pune
iv)	Raigarh (Kotra) – Champa (Pool) 765/400kV 2 nd S/C line.
v)	Champa (pool) – Dharamjaigarh 765kV 2 nd S/C line.

2. The scope of works mentioned above, has been agreed in the 36th Standing Committee Meeting on Power System Planning of Western Region held on 29.08.2013.
3. CEA conveys the prior approval of Government under Section 68(1) of Electricity Act, 2003 for the scheme System Strengthening for IPPs in Chhattisgarh and other generation projects in Western Region with above scope of works to M/s **Chhattisgarh – WR Transmission Limited**.
4. This approval is subject to compliance of
 - a) The requirement of the relevant provisions of the Electricity Act, 2003, as amended from time to time and the rules and regulations framed thereunder and
 - b) CEA's (Measures relating to Safety and Electrical Supply) Regulations, 2010 framed under the Electricity Act, 2003.
5. The approval is also subject to the following conditions:
 - i) The implementing agency will commence construction of the project within three years, unless this term is extended by the Central Electricity Authority.
 - ii) Central Electricity Authority may withdraw the approval before the expiry of the period of three years after giving a one-month notice.
 - iii) The implementing agencies shall abide by the provisions of Works of Licensee Rules, 2006 notified by the Government of India, Ministry of Power in the Gazette of India, extra-ordinary Part-II, Section 3(i) dated 18-04-2006 (vide GSR 217 (E) dated 18-04-2006),


 (P.D Siwal)
 Secretary, CEA.

Copy to: - Joint Secretary (Trans), Ministry of Power, Shram Shakti Bhawan, Rafi Marg, New Delhi.