

CHIEF ENGINEER (NATIONAL HIGHWAY) PUNJAB PWD (B&R)
C-BLOCK NIRMAL BHAWAN, MINI SECRETARIATE, PATIALA.

To

The Superintending Engineer,
Central Works Circle, PWD B&R,
Ferozepur

Memo No.

135

/NH

Dated:

08/01/15

Subject:

NOC case for Laying Water Pipe line from Kamalwala minor to Vill.
Hiranwala Teh.&Disst. Fazilka on DHS Road NH-10(07) Sec. Abohar-
Fazilka km.395.15-400.60


Ref:

Your office letter No. 853 dated 18.12.2014 on the subject cited above.

As per recommendation received vide your letter under reference, the approval to issue No Objection Certificate (NOC) is hereby accorded subject to the following conditions:

1. The Water Pipe line shall be located as close to the extreme edge of the ROW as possible.
2. The Water Pipe line shall not be permitted to run along the National Highway, when the road formation is situated in double cutting. Nor shall these be laid over the existing culverts and bridges without the prior approval of Govt. of India.
3. The Water Pipe line shall be so placed that at no time there is interference with the maintenance of the National Highway and there is no interruption of the flow of traffic during and after execution.
4. These should be laid strictly as per drawing by adopting confined cut excavation method as otherwise directed by the Highway authority so as no to obstruct drainage of the road land. The refilling of the trenches shall be as per MORT&H specifications.
5. For all the major bridges of 60m or more in length to be constructed in future on NH, the requirements of the concerned department should be ascertained in advance, and suitable provision in the form of the ducts etc. made in the project estimate.
6. The agency shall take prior approval from this department before undertaking any work of installation, shifting of repairs, or alterations, to Water Pipe line
7. Expenditure if any, by this department (Highway Authority) for repairing any damage cost to the road by the laying, maintenance of shifting of Water Pipe line will be borne by the agency.
8. If the department considers it necessary in future to move/remove the Water Pipe line for any work of improvement or repair of road, it will be

For Secretary, PWD B&R, Patiala


Director