

Annexure

Combined Water Supply Scheme to 135 rural habitations in Vaiyampatti and Marungapuri Unions in Trichy District.

I enclosed herewith the Trench Size and Pipe details of the proposal.

Sl.No	Description	Trench Depth in Meters	Trench Width in Meters	Pipe Details
1	Segment 1	1.05	0.6	50 mm PVC
2	Segment 2	1.05	0.6	110 mm PVC
3	Segment 3	1.05	0.6	50 mm PVC
4	Segment 4	1.05	0.6	75 mm PVC
5	Segment 5	1.05	0.6	63 mm PVC



Executive Engineer,

TWAD Board

RWS Division, Trichy