

OFFICE OF CHIEF ENGINEER PROJECT.



PUBLIC HEALTH ENGINEERING DEPARTMENT, JODHPUR

No:CEP/PHE/AE/ 2020-21/11460-11462 Date 22-1-2021

Additional Chief Engineer RGLC
PHED Jodhpur

Sub: Permission to Power Grid Corporation of India Limited for overhead crossing of Rajiv Gandhi Lift Canal by 400 KV Bhadla (PG) - Bhadla 2 line over RGLC RD 32.33 Km (Mandli) (Tower No. 240 & 2570)

Ref: Your letter no. 1706-1709 dated 15.01.2020

As recommended by you and based upon approval granted at the level of Principal Secretary PHED vide his ID No. 1774/13.8.2020 in similar case of Power Grid Corporation (a Govt Enterprises) for the overhead crossing of Rajiv Gandhi Lift Canal between RD 60 and 61; the permission is granted subject to taking affidavit from the applicant and following conditions:-

1. applicant shall maintain minimum clearance of 23.491/16.147m (as recommended by you in your letter) for the lowest conductor under the maximum sag condition of 85° C, above the canal bank & shall follow all safety precautions as per relevant code;
2. applicant shall be solely responsible for stability and safety of transmission line;
3. in future, if any tower is required to be shifted due to widening/modification of RGLC, then applicant shall be liable to shift the poles & all the cost for shifting of towers shall be borne by them.
4. towers of transmission line shall be erected outside RGLC Canal land strip;
5. no component of RGLC Phase III should be affected due to this permission.

(Neeraj Mathur)
Chief Engineer Project
PHED, Jodhpur

No:CEP/PHE/AE/Power Grid/ 2020-21/11460-462 Date 22-1-2021

Copy to following for pursuance with RWSSMB.

1. Superintending Engineer PHED Project Circle Jodhpur
2. Executive Engineer PHED RGLC Dn II Jodhpur

(Neeraj Mathur)
Chief Engineer Project
PHED, Jodhpur

उप वन संरक्षक
जोधपुर

Jal Bhawan, Basni, Jodhpur - 342 005 (Rajasthan) Tel. 0291-7651700 Email rj_cesjod@nic.in

कुमार गौतम / Kumar Gautam
उप निरीक्षक / Asst. Engineer
Powergrid Co. Ltd.
400 KV D/C Bhadla (PG) (Const.)

No.T- 1975

Dated. 16-12-2020

DGM

Power Grid Corporation of India Limited
400 KV D/C Bhadla (PG) Bhadla 2 (T/L Const.)
Nandpuri colony Nagaour Road, Phalodi
Distt. Jodhpur

Sub- Appoval for canal crossing by PGCIL 400 KV BHADLA (PG) BHADLA2 line cover kumar
minor canal near badi sid (Tower No 304/5& 30A/6)

Ref:- Your office letter No. NR-1/BDL -2/TLT/1147 Dated 1-6-2020


Sir,

With reference to letter cited above vide which you have submitted the case to accord permission for construction of for over head crossing of Kumhar Minor by loop out portion of LIL of 400 KV D/C Bhadla 2 to Bhadla (PG) Line (twin HTL-S) over Head Crossing over km 2.130 of Kumhar Minor.

In this contest, the permission for over head crossing of power line to power Grid corporation of India Limited is here by conveyed with the following conditions:-

1. The flow of water in the Canal & both's side, the inspection bank (25 feet wide) should not be obstructed, so as to inspection from both side could be conducted.
2. The work will have to be got executed by the Power Grid Corporation of India Limited Authority in running water and closure in Canal will not be provided in any conditions at any stage.
3. The NOC for land required for any type of structure, be taken by the PGCI Ltd Authority from the respective competent authority.
4. The restoration work of Canal, if found any damage at the time to crossing of power line will have to be got done then and there.
5. The work will have to be got executed under the supervision of the Assistant Engineer, sub Dn-III, IGNP Girajsar
6. The de-silting work of Canal done by Middle Boom Machines (approx 40' long boom) therefore safe height of line cross over canal will be considered accordingly.

Yours faithfully


(Dinesh Singh Solanki)
Executive Engineer
Kolayat Lift Division,
IGNP Bikaner

Dated.

No.T-

1. Copy to Assistant Engineer, sub Dn-III, IGNP Girajsar for information & necessary action.


कुमार गौतम / Kumar Gautam
उप महसुब / DGM
Powergrid Corporation of India Ltd.
400 KV D/C Bhadla (PG)-Bhadla-2 (T/L Const.)


उप वन संरक्षक
जोधपुर
/—
Executive Engineer

कार्यालय अधीक्षण अभियन्ता फलोदी निर्माण एवं रख रखाव वृत्त इगानप फलोदी

Annexure-1

क्रमांक - 312/फलोदी/रख/3630

दिनांक - 23/12/2020

अधीशापी अभियन्ता
24 वॉ खण्ड इगानप
फलोदी

विषय:- PGCIL 400 KM BHADLA (PG) -BHADLA-2 प्रसारण लाईन व तंत्र के निर्माण के लिए नहरों की क्रॉसिंग की अनुमति के सम्बन्ध में।
प्रसंग:- आपका पत्रांक 8327 दिनांक 09.12.2020

महोदय,

उपरोक्त विषयान्तर्गत एवं संदर्भित पत्र के द्वारा नहर क्रॉसिंग की स्वीकृति हेतु अनुशंसा सहित प्रकरण प्रस्तुत किया गया है।

उपरोक्त संदर्भित पत्रांक के तहत प्रसारण लाईन एवं तंत्र निर्माण के लिये नहर क्रॉसिंग की अनुमति आप द्वारा की गई अनुशंसा के आधार पर निम्न शर्तों पर आपको प्रदान की जाती है।

1. प्रसारण लाईन लगाने के दौरान नहर, पट्टी, साईड स्लोप एवं निरीक्षण बैंक पर किसी प्रकार का व्यवधान नहीं उत्पन्न होना चाहिए।
2. नहर पट्टी, साईड स्लोप को किसी प्रकार की क्षति नहीं पहुंचायी जावे।
3. प्रसारण लाईन व तंत्र लगाने के दौरान नहर के प्रवाह में किसी तरह की बाधा नहीं आनी चाहिए।
4. नहर की डिसिल्टिंग का कार्य Long boom Machines से करने पर (जिसकी बूम लम्बाई करीब 60 फीट) किसी तरह की Operational अडचन प्रसारण लाईन के कारण नहीं होनी चाहिए।
5. नहर क्रॉसिंग हेतु फर्म/कम्पनी द्वारा करवाया जाने वाला कार्य अधीशापी अभियन्ता 24 वॉ खण्ड इगानप फलोदी की देखरेख में करवाया जावे।
6. प्रसारण लाईन हेतु भूमि की आवश्यकता होने पर फर्म/कम्पनी द्वारा सक्षम स्तर से अलग से सम्बन्धित विभाग से अनुमति प्राप्त करनी होगी।
7. प्रसारण लाईन लगाने के दौरान नहर तंत्र को किसी भी तरह की क्षति होने पर सम्बन्धित फर्म की जिम्मेदारी रहेगी।
8. सम्बन्धित नहर की सीमा क्षेत्र में यदि उक्त प्रसारण लाईन के लगाये जाने से, इरेक्शन के दौरान अथवा भविष्य में यदि किसी प्रकार की दुर्घटना उत्पन्न होती है तो इसके लिये विभाग उत्तरदायी नहीं होगा तथा सम्बन्धित फर्म/कम्पनी ऐसे समस्त उत्तरदायित्वों/दावों की जवाबदेही हेतु बाध्य होगी।
9. यदि नियमावली/गाईडलाइन्स में ऐसा कोई प्रावधान हो तो नहर के मापदण्डों के अनुरूप आपके स्तर से उचित राशि तय कर सम्बन्धित फर्म/कम्पनी से बतौर अमानत राशि खण्ड कार्यालय में प्राप्ता की जावे। अमानत राशि नहर के मापदण्डों के अनुरूप आपके द्वारा निर्धारित की जावे।
10. प्रसारण लाईन लगाने के दौरान केन्द्रीय विद्युत प्राधिकरण की गाईड लाईन/ नियमावली की पालना सुनिश्चित की जावे।
11. लिफ्ट नहर पर निर्मित पम्पिंग स्टेशन/रिहायशी आवासों से इरेक्शन होने वाली प्रसारण लाईन के एलाइमेंट की समुचित दूरी पर होनी सुनिश्चित किया जावे।
12. कम्पनी द्वारा प्रस्तुत ड्राईंग का समुचित अध्ययन आपके द्वारा कर नहर सुरक्षा एवं रख रखाव वाचन आवश्यक कार्यवाही किया जाना सुनिश्चित करे।

उपरोक्त के अतिरिक्त मौका स्थितिनुसार अन्य कोई शर्त आपको उचित लगे तो उसका समावेश करते हुए आपके स्तर से फर्म/कम्पनी को अनापत्ति पत्र जारी करें।

क्रमांक - 2857
दिनांक - 5-1-24

क्रमांक

प्रतिलिपि श्रीमान् अति-मुख्य अभियन्ता इगानप बीकानेर को सूचनार्थ प्रस्तुत है।
30/12

अधीक्षण अभियन्ता
फलोदी निर्माण एवं रख रखाव वृत्त
इगानप फलोदी

दिनांक

उप वन संरक्षक
जोधपुर

कुमार गौतम / Kumar Gautam
उप महाप्रबंधक / DGM
Powergrid Corporation of India Ltd.
400 kV D/C Bhadla (PG)-Bhadla-2 (T/L Const.)

अधीक्षण अभियन्ता
फलोदी निर्माण एवं रख रखाव वृत्त
इगानप फलोदी



भारतीय राष्ट्रीय राजमार्ग प्राधिकरण
(सड़क परिवहन और राजमार्ग मंत्रालय)
National Highways Authority of India
(Ministry of Road Transport & Highways)
परियोजना कार्यान्वयन इकाई, बीकानेर
Project Implementation Unit, Bikaner
सी-38, सादुल गंज, बीकानेर (राजस्थान) - 334002
C-38, Sadul Ganj, Bikaner (Raj.) - 334002

दूरभाष / Phone: 0151-2224477
फैक्स / Fax: 0151-2224077
ई-मेल / E-mail: bikaner@nhai.org
nhaibikaner@gmail.com



भारतमाला

प्रगति के पथ पर अग्रसर
Date: 14.10.2020

No.13181/1/2020/NOC-OFC&TL(BM-10)/7358

Reg. Post

Sh. Kumar Gautam
Dy.General Manager
M/s.Powergrid Corporation of India Ltd.
400 KV D/C Bhadla (PG)-Bhadla-2 (T/L Const.)
785/400 KV Sub-station (Const.) Bhadla-II,
115 Nandpuri Colony, Nagour Road
Phalodi-342301 Distt.Jodhpur

Sub : Proposal for overhead crossing clearance of NH-911 from Bap-Sriganganagar at milestone no.168/750 and 168/850 near village Manchitiya (Distt.Jodhpur) by 400 KV D/C Bhadla (PG)-Bhadla 2 TL-reg.

Ref: Your Letter No.TPL / PGCIL / Bhadla 2 / TL/786 dated 17.08.2020.

Sir,

Refer your letter under reference above vide which you have submitted a Proposal for overhead crossing clearance of NH-911 from Bap-Sriganganagar at milestone no.168/750 and 168/850 near village Manchitiya (Distt.Jodhpur) by 400 KV D/C Bhadla (PG)-Bhadla 2 TL.

In this regard, the License Fee/Lease rentals applicable, as per Ministry guideline No. RE/NH-33044 /29/2015/S&R (R) dated 22.11.2016 is required to be deposited by you. Accordingly the rental fee payable has been calculated which comes to Rs. 4811.40.

The above rental fee has been calculated for 495 sq.mtr. length of NH, where utility corridor is available for overhead crossing.

Therefore, you are requested to deposit lease amount of Rs.4811.40 through NTRP/Bharatkosh Portal of Govt. of India as per calculation sheet attached so that the proposal can be forwarded to RO, NHAI, Jaipur for further action in the matter.

Further, you are requested to submit the performance Bank Guarantee @ Rs.100/- per route meter as per Ministry's Circular no. RW/NH-33044/29/2015/S&R (R) dated 22.11.2016 amounting to Rs.49,500/- (495 sq.mtr x Rs.100/-) valid for a period of one year in favour of Project Director National Highways Authority of India, Bikaner.

Yours Faithfully,

कुमार गौतम / Kumar Gautam
उप महाप्रबंधक / DGM
Powergrid Corporation of India Ltd.
400 KV D/C Bhadla (PG)-Bhadla-2 (T/L Const.)

परियोजना निदेशक / Project Director
राजस्थान राजमार्ग विकास प्राधिकरण
उप वन संरक्षक
जोधपुर

मुख्यालय: जी-5 एवं 6, सेक्टर- 10, द्वारका, नई दिल्ली - 110075 दूरभाष 01125074100/200 फैक्स 011-25093507 Web: www.nhai.org
Head Office: G-5 & 6, Sector-10, Dwarka, New Delhi-110075, Phone: 011-25074100, 25074200 Fax: 011-25093507