

HIMACHAL PRADESH STATE ELECTRICITY BOARD LIMITED

(A STATE GOVERNMENT UNDERTAKING)



Registered Office:- HPSEBL, Vidyut Bhawan, Shimla-171004 (H.P.)
CIN: U40109HP2009SGC031255
Tele-Fax: 01772653656
Website: www.hpseb.com,
Email: cesp.hpseb@gmail.com, seplanning.hpseb@gmail.com

No. HPSEBL/CE (SP)(IPSP)/DB-W-65(A)/ NP/ Vol-VIII/2018- 6040-42 Dated:- 12¹¹/₂18
To

The General Manager (C&D),
HPPTCL, Him Fed Bhawan,
Panjari (Below old MLA Quarters),
Shimla-171005.

Subject: - Transmission system for evacuation of power from Suket SHEP (1.0MW).
Sir,

Enclosed please find herewith a copy of letter Nil dated Nil received from M/s Mohan Singh Thakur vide which he has requested to allow him to evacuate the power of Suket project (1.00MW) through solid tap on existing 11kV local Mangwain feeder at village Mandi (Near Puhlghrat)/.

In this regard, it is to intimate that the evacuation of power from Suket (1.0MW) can be allowed through solid tap on 11kV local Mangwain feeder subject to the following conditions:-

- 1 The cost of 11kV line from Suket (1.0MW) to tapping point at village Mandi (Near Puhlghrat) by LILO arrangement or by installing auto re-closures including interconnection facilities shall be born by the developer.
 - 2 At the time of actual interconnection of power house on 11kV Mandi -Mangwain feeder if necessity arisen, the cost for augmentation of existing conductor of this feeder shall also be born by the developer.
 - 3 No deemed generation shall be allowed to the developer in case of Shutdown / breakdown of 11kV Mandi-Mangwain feeder and 33/11kV sub-station Mandi.
 - 4 The loss adjustment, if any, from interconnection point to 33/11kV sub-station Mandi shall be born by the developer as per prevailing guidelines of HPERC.
- It is therefore, requested that further action in the matter may be taken at your end please.

Yours faithfully,

Chief Engineer (SP),
HPSEBL, Uttam Bhawan,
Dogra Lodge, Shimla- 4.

Copy to the following for information please:-

- 1 The Chief Engineer (Op), Central Zone, HPSEBL., Mandi (HP) w.r.t. his letter No. HPSEBL/CEOCZ/DB-6/2018-19-8600-01 dated 8.09.2018.
- 2 M/s Mohan Singh Thakur R/o 75/11, Tarana Hills Mandir, Distt. Mandi-175001 (HP) w.r.t his consent / undertaking dated 29.10.2018.

Chief Engineer (SP),
HPSEBL, Uttam Bhawan,
Dogra Lodge, Shimla- 4.