



## ನಗರಸಭಾ ಕಾರ್ಯಾಲಯ ಚಿಂತಾಮಣಿ ಚಿಕ್ಕಬಳ್ಳಾಪುರ ಜಿಲ್ಲೆ.

ನಂ.ನಸಚಿ/ತಾಶಾ/ಸಿಆರ್/132/2019-20

ದಿನಾಂಕ:11/05/2020

To,

The Noda Officer and  
Addl Principal Chief Conservative of Forests,  
(Forest Conservation Bengaluru).

Sir,

Sub : ADDITIONAL INFORMATION REGARDING CLARIFICATION ON  
WATER PIPE AND 11 KV EXPRESS FEEDER LINE.

The project named DIVERSION OF FOREST LAND NEAR BHAKTHRAHALLI ARASIKERE, CHINTAMANI TALUK, CHIKKABALLAPUR DISTRICT FOR CONSTRUCTION OF HOUSING CHAMBER, LAYING OF PIPELINE & 11 KV EXPRESS FEEDER LINE FOR PROVIDING WATER SUPPLY SCHEME TO CHINTAMANI CITY WITH BHAKTHRAHALLI ARASIKERE AS SOURCE UNDER D.C. WORKS UNDER NAGAROTHA-III GRANTS IN FAVOUR OF COMMISSIONER, CMC, CHINTAMANI PROPOSAL NO.FP/KA/WATER/44628/2020 being uploaded in online e-portal.

Sl No.	Observation	Clarification
C (i)	<b>Water pipeline</b> : Diameter ( within forest land limits) and whether it is to be laid underground or over ground. If underground, at what depth?	The 355.60 mm dia Mild Steel water pipeline is to be laid underground at a depth of 1.20 meter.
C(ii)	<b>11 KV Express feeder line</b> : Whether it is to be laid underground or over ground? It is note that, if it is proposed over ground, the 7 meter right of way as prescribed for the 11 KV transmission line in FC Guidlines(	*) 11 KV express feeder line is to be laid over ground. *) Yes- 7 metre right of way as prescribed for the 1 KV transmission line, and adopted 7 meter wide in calculation of

	available on FC web portel) needs to be adopted for calculating forest and non-forest land requirements	forest and non forest land.
C(iii)	Whether the water pipeline is to be laid within the 7 meter right of way of overhead 11 KV express feeder line? If yes upload the cross section of the forest strip showing the components in the entire width.	Yes - The water pipeline is to be laid within the 7 meter right of way of overhead 11 KV express feeder line. ( Drawing Uploaded )
C(iv)	If the water pipeline and 11 KV express feeder line are to be laid separately, please specify the width of the forest strip required for each of them.	No - The water pipeline and 11 KV express feeder line is to laid within the 7 meter of forest land and non forest land. (It is marked in the Uploaded drawing).

Thanking you,

Yours faithfully,

Commissioner  
CMC, Chintamani. 1/5/20