



SPECIFICATION NOTES:-

1. EXCEPT THAT CONNECTED WITH RETRO PUMP WITHOUT THE PRIOR APPROVAL OF P.W.D.
2. THE PUMP SHALL BE PROVIDED WITH A 150MM DIA. CAST IRON SERVICE STATION.
3. THE PUMP SHALL NOT AFFECT THE FUTURE IMPROVEMENT OF THE ROAD.
4. CERTIFIED THAT NO OTHER RETRO PUMP EXISTS WITHIN THE DISTANCE OF 100M ON EITHER SIDE OF THE ROAD.
5. CERTIFIED THAT ALL CONDITIONS LAD DOWN BY THE GOVT. OF INDIA AND ISR FROM TIME TO TIME SHALL BE STRICTLY FOLLOWED.
6. NO DRAIN, SEWER OR STRUCTURE WITHIN 1.5M FROM UNDER GROUND TANKS.
7. ALL ELECTRICAL WIRING SHALL BE IN CONFORMANCE WITH THE ISIRI STANDARDS.
8. ELECTRICAL FITTINGS CONFORM TO IS CODE NO-2148 FOR CORRESPONDING PUMP ONLY.
9. ALL ELECTRICAL WIRING SHALL BE IN CONFORMANCE WITH THE ISIRI STANDARDS.
10. OPENING VENT PIPES, AIR HIGH FROM GROUND LEVEL AND AN CLEAR AIR DUCT, THE OPEN END OF THE PIPE SHALL BE COVERED WITH TWO LAYERS OF NON-CORROSION METAL WIRE GAUGE OF 15MM PER LINE ON.
11. BONDING FILL PIPES, TO BE PROVIDED 3.5M CLEAR ALL ROUND.
12. 4 NOS. 75MM TYPE OF FIRE EXTINGUISHERS OF CAPACITY 4KG EACH FOR RETRO PUMP, 2 NOS. 75MM TYPE OF FIRE EXTINGUISHERS OF CAPACITY 4KG EACH FOR OPEN LAND SHOPS AND 2 NOS. OF FIRE EXTINGUISHERS OF CAPACITY 4KG EACH FOR OPEN LAND RESIDENCE.
13. CERTIFIED THAT THE SITES ARE NOT IN ANY OF THE NOTIFIED ZONES.
14. CERTIFIED THAT THE SITES ARE NOT IN ANY OF THE NOTIFIED ZONES.
15. CERTIFIED THAT ALL THE CONDITIONS OF FC-1987/2003 SHALL BE COMPLIED WITH.

INDICATIVE NOTES:-

1. CERTIFIED THAT ALL THE CLEARANCES APPROXIMATELY FROM HOPIFC AND OTHER RELEVANT GOVT. AT PARAN N.P.
2. CERTIFIED THAT NO COAST GUARD IS PENDING IN ANY COURT OF INDIA AGAINST THIS SITE/SHEDSHIP.
3. CERTIFIED THAT ALL THE CLEARANCES APPROXIMATELY FROM HOPIFC AND OTHER RELEVANT GOVT. AT PARAN N.P.
4. CERTIFIED THAT ALL FACILITIES AS SHOWN IN THE DRAWING SHALL BE INSTALLED/PROVIDED AT PARAN N.P.

SPECIFICATIONS FOR TANKS:-

1. 150 TANK OF 20M CAPACITY FABRICATED AS PER DRG. APPROVED BY CCE VIJAY NER. NO. PWD/11 DATED 29.03.2007.

SITE INFORMATION	
VILLAGE	KALUWAS
ROAD	BHIMANI-CHITSAKARA ROAD(SH-164)
RAILWAY STATION	BHIMANI
POLICE STATION	BHIMANI
TELEPHONE OFFICE	BHIMANI
POST OFFICE	BHIMANI
POSTAL CODE NO.	567253, 577192, 21 & 22

LAYOUT PLAN SCALE:- 1:200

TOTAL PLOT AREA - 484 SQ. M.
TOTAL BUILDING AREA - 19.5 SQ. M.

AREA CALCULATION

PROTECTED FOREST FOR APPROACH ROAD
 $A+B = 2(7.8X8.5) = 132.6 \text{ SQ.M.}$
 $A+B = 2(11.2X5.5-2/3X7.07X1.46) \text{ SQ.M.}$
 $= 2(12.50-6.88) = 11.24 \text{ SQ.M.}$
TOTAL = 143.84 SQ.M. OR 0.014384 HAC.

REV. NO.	DESCRIPTION	DATE	REV. BY	APP. BY
	INDIAN OIL CORPORATION LIMITED (MARKETING DIVISION) HISSAR DIVISIONAL OFFICE			

PROJECT:-
 PROPOSED RETAIL OUTLET - KALUWAS, ON BHIMANI-CHITSAKARA ROAD (SH-164), HISSAR & DISTT. BHIMANI (HARYANA), PIN-131001.
TITLE:- SITE & LAYOUT PLAN

DRAWN:-
 P.K. DRG. NO. IN/2003/001/CHITSAKARA/BHIMANI
 DATE:- 27.03.2016
 APPROVED:-
 SCALE:- 1:200
 PREPARED BY:
 SALES OFFICER DR. MANJESHA MANAGER-ROZEE
 HISSAR ASSOCIATES
 HISSAR (HARYANA), PIN-131001

DR. RAJESH K. RAJPAL
 Manager (Retail Sales)/Manager (R.S.)
 Hissar Divisional Office
 Indian Oil Corporation Ltd.
 Hissar - 125005/Hissar - 125005