



# यूजेवीएन लिमिटेड

(उत्तराखण्डसरकारकाउपक्रम)

## UJVN Limited

(A Govt. of Uttarakhand Enterprise)

कार्यालय अधिशासी अभियन्ता (जानपद- लजविप) 33 के0वी0उपसंस्थानपरिसर, हाट, धारचूला, जिलापिथौरागढ़ दूरभाष: 05967-220240, फैक्स: 05967-220245  
Office of the Executive Engineer (Civil – SHP), 33 KV Sub Station Complex, Hat, Dharchula, Dist. Pithoragarh Tel.: 05967-220240, Fax: 05967-220245

CIN: U40101UR2001SGC025866

No.: 32/UJVNL/03/Director Projects/EE(C-Dharchula)/L-1

Dated: 28/04/2021

✓ Divisional Forest Officer,  
Pithoragarh, Forest Division,  
Pithoragarh.

**Subject: Regarding transfer of 9.397 hac forest land for construction of 4 x 3 MW Tankul SHP at tehsil Dharchula of district Pithoragarh in the name of UJVN Limited (FP/UK/HYD/42080/2019).**

Sir,

Kindly refer observations raised by Ministry, MoEF, New-Delhi vide letter no. 8B/U.C.P./01/195/2019/F.C./2476 dated 17/03/2021. In this context, point wise replies to observations are as follows:-

S.No.	Observation	Reply
1.	In reply to point no. 01 state government was requested to submit the enabling provisions prescribing charging of lease rent @ 1% of the total value of the forest land as no such provisions have been provided under FC act, 1980. State Government submitted that the same desired by Uttarakhand Government vide letter dt. 09.09.2005. Which show that the reply is just a copy of the reply submitted by the user agency. State Government is requested to submit the enabling provision for charging of lease rent.	The clarification regarding lease rent may kindly be provided by your good office. All requisite compensatory levies such as CA, NPV and other project specific levies shall be borne by UJVNL.
2.	In reply to point no. 02, state government again forwarded the reply of user agency without examining at their level. User agency informed that they are already having 33 kV substation and in addition also having 11 kV transmission line and the same shall be upgraded to 33 kV line for evacuation of power. It is submitted that RoW approved for 11 kV line is 7 mtr and for 33 kV is 15 m. State government may submit clarification in this regard.	No land has been included for transmission line from Tankul SHP to 33 kV Sub Station, Tawaghat in land case under consideration. Shape of the land to be diverted for construction of 33 kV transmission line is liner. If required, separate land case shall be prepared for acquiring additional land for construction of 33 kV transmission line. UPCL has also proposed 33 kV line from Sub Station, Tawaghat to Gunji which shall pass through 12 MW Tankul SHP.

3.	In reply to point no. 03, State government is requested to submit the revised muck disposal plan after incorporating swell factor.	Balance quantity of muck i.e. 26263 cum after considering swell factor shall be disposed of at quarry site and shall also be used locally in construction activities at the project camp building area. (Calculations enclosed).
4.	In reply to point no 04, neither any administrative approval found enclosed with the letter nor found uploaded online. State government may submit the administrative approval of the project.	D.P.R. of the project was approved by the board of UJVNL. Board of UJVNL having Secretary Energy, GoU as Chairman and whole time Managing Director & Directors of UJVNL as members including part time Directors. Approval of DPR of Tankul SHP by Board of Directors is administrative approval of the project. (Copy of approval enclosed).

Enclosures: As above.

*Rishi Singh*

**(Rishi Singh)**  
**Executive Engineer**

अधिशाली अभियन्ता (जानपद-लजविप)  
यूजेवीएन लिमिटेड  
धारचूला, पिथौरागढ़