

HIMACHAL PRADESH STATE ELECTRICITY BOARD LIMITED
(A STATE GOVERNMENT UNDERTAKING)



Registered Office: HPSEBL, Vidyal Bhawan, Shimla-171004 (H.P.)
CIN: U40109HP200980CO31233
Tele-Fax: 01772653656
Website: www.hpsebl.com
Email: info@hpsebl.com; generalmanager@hpsebl.com

No. HPSEBL/CE(SP)/(IPSP)/DB-65(A)NP/ Vol-X/2021 2138-40 Dated:- 21/02/2021
To

M/s Behl Motors,
Plot No. 6&7, Industrial Area,
Phase-III, Sauli Khad, Mandi (HP).

Sub:- Feasibility for connectivity of Jiwa-II SHEP (1.75MW).

Ref:- Your office letter no. Nil dated 21.01.2021.

This is in reference to your office letter cited above, it is intimated that the power evacuation of Jiwa-II SHEP (1.75 MW) is feasible at Raila Spur of 11kV Neuli feeder emanating from the existing 33/11kV, 2x3.15 MVA Sub-Station Sainj by making arrangement for the interconnection facilities near the JSV lift water scheme. The evacuation arrangement is subject to the following terms & conditions:-

- 1 IPP shall bear the cost of providing interconnection facilities and 11kV HT Line from the power house to said interconnection point. Necessary right of way (ROW) for the HT Line and land for the interconnection facilities shall also be arranged by the IPP.
- 2 Losses at 11kV from interconnection point to 33/11 kV S/Stn. Sainj shall be borne by the IPP.
- 3 No deemed generation shall be allowed.

It is therefore requested that the consent of the above terms & conditions on the non-judicial stamp paper should be submitted to this office for further perusal of the case.

S/S 19/8
(Er. S. K. Dhiman)
Chief Engineer (SP),
HPSEB Ltd. Uttam Bhawan,
Dogra Lodge, Shimla-171004.

Copy of above is forwarded to the following for information and necessary action please:

- 1 The Chief Engineer (Op), Central Zone, HPSEBL, Mandi (HP).
- 2 The General Manager (C&D), HPPTCL, Himfed Bhawan, Panjeri (Below Quarters), Shimla-171005.

S/S 19/8
Chief Engineer (SP),
HPSEB Ltd. Uttam Bhawan,
Dogra Lodge, Shimla-171004.

For

And