


QUERY NO.3

The Para 10.2 of FCA Handbook 2019 Specify only the dimensions of trench whereas para 10.1 specify width of right of way for high voltage distribution lines but unfortunately we cannot clear width of right of way for underground cable in FCA Handbook 2019.

For bare conductor 11 KV line width of right of way is 7 MTR that's why we consider width of right of way for underground cable approximately 5 MTR for safety precautions, also we have to state that we will not utilize the 5 MTR width span for any other purpose other than mentions in attached sketch of page no.2. In the 5 MTR width span we are not going to do any kind of tree cutting unless it is utmost necessary, and also this width of 5 MTR will help us in honorable GOG ask for any future expansion.


Executive Engineer (City)
P.G.V.C.L., JUNAGADH


Deputy Engg.
P . G . V . C . L .
Gandhigram S/Dn.
JUANGADH.