

Minimum Distance of Lowest Conductor above the ground-- Ground Clearence

Sl.No.	Location No.	Tower Type	Minimum Distance (Sag in mtr)	Forest Division
1	AP 13/1	DA + 0	10.50	Sonitpur East
2	AP 14	DB + 0	7.90	Sonitpur East
3	AP 15	DD + 0	8.00	Sonitpur East
4	AP 16	DC + 0	11.30	Sonitpur East
5	AP 17	DC + 0	12.40	Sonitpur East
6	AP 18	DC + 0	8.20	Sonitpur East
7	AP 18/1	DA + 0	9.00	Sonitpur East
8	AP 19	DD + 0	10.40	Sonitpur East
9	AP 20	DD + 0	6.60	Sonitpur East
10	AP 21	DD + 0	8.10	Sonitpur East
11	AP 22	DD + 0	9.20	Sonitpur East
12	AP 22/1	DA + 0		Sonitpur East


05.22
उप मुख्य विद्युत इंजीनियर (निर्माण)/आर ड
Dy. Chief Electrical Engineer (CON)/RE
पू० सी० रेल, मालीगांव
N. F. Railway, Maligaon