

HARYANA PWD (B&R) PROVINCIAL SUB DIVISION KHARKHODA

To

The Executive Engineer Provincial Division No.1 PWD B&R Br. Sonepat

Memo No: -

432

Dated: 02/04/18

Subject: -

Regarding release of genuineness certificate for institutional site for Aurora Foundation at village Nahra, Distt. Sonepat.

Ref .: -

Your letter No. 15425 dated 16.12.17

The above said case as received vide letter under reference is hereby submitted with the report that this site is inspected by the undersigned along with concerned J.E. and this office has no objection regarding the genuineness certificate as under:-

- 1. The proposed site is situated on Jharoth Narela road.
- The Pucca structure / School building shall be constructed beyond the PWD boundary.
- 3. If the agency/applicant used the PWD land for the access to the building, the agency will deposit lease money as per norms.
- 4. The agency will keep plinth level of School Building at least 20 cm below the level of road.
- 5. The slope of the access/ approach should not towards the road.
- 6. If the up gradation of road is required in future, the approach shall be demolished without any notice and no claim in this regard shall be entertained.
- 7. All safety majors must be followed by the applicant during the construction of building.

DA/as received

Sub Divisional Engineer Provincial Sub Division PWD B&R Br. Kharkhoda