

Annexure-8.

Amoruf-23

AGE CIVIL/SID PTA/SHRIMON/C.A./JHUMIUDU

SR.XEN/TL DIV. PSPCL, PATIALA

PSPCL

Punjab State Power Corporation Limited

(Regd. Office: PSEB Head Office, The Mall, Patiala)

Office of SE/TL (Design), B-1, Shakti Vihar, Patiala.

Corporate Identity No. U40109PB2010SGC033813 Website: www.pspcl.in

Telephone: 0175-2303093

Fax: 0175-2303093

e-mail: setransdesign@gmail.com

To

Dy. CE/TL Circle,
PSPCL, Patiala.

Memo No/261/62 /TSR-459

Dated: 8.05.2019

Subject:

Route Plan of 66 kV Devigarh - Rohar Jagir line T-off for 66 kV S/S Bhasmara (SC on DC).

Ref:

Your office memo no. 1852 dt. 24.04.2019.

Subject cited route plan submitted vide your letter under reference has been technically concurred with corrections/comments on drawing subject to the following conditions:

1. The technical concurrence is being given strictly as per recommendations of SE/TL Circle, PSPCL, Patiala and Sr. Xen/TL Div., PSPCL, Patiala purely on technical basis.
2. Before taking work in hand all instructions of PSPCL amended from time to time must be followed.
3. All clearance shall be maintained as per Electrical Rules/PSPCL Norms while executing the job.
4. The instructions issued vide CE/TS memo no. 4587 dated 27.05.2016 shall be complied with.
5. The dismantled material, if any, shall be returned to stores.

One copy of technically concurred route plan alongwith Quality Control Register No. TS- is enclosed herewith for further necessary action.

DA: As above.

CC:

1. Addl. S.E., TL Div., PSPCL, Patiala.
2. UDC for notification

Addl. SE/TL-II,
PSPCL, Patiala

For information & necessary action.

Length of line 6.170 CKI. KM, ACSR size 0.2 sq. inch

COUNTERSIGNED
PSPCL, PATIALA

Sr. Executive Engineer,
T.L.Division, P.S.P.C.L., Patiala

25 NOV 2019