


Site Inspection Report of the Deputy Conservator of Forests

I have inspected the proposed site on 13.04.2018. The proposal is to draw 0.381 Km LT single phase OH line through the coupe road of Thannippoyil 2004 TP in Pokkode Reserve Forest under Akampadam Forest Station in Edavanna Range of Nilambur North Forest Division, for electrifying the houses at the private land situated as an enclosure in the above forest area.

As the electrical lines are not passing through dense forest, tree cutting is almost nil as mentioned by the user agency in the project proposal. Moreover, the user agency have submitted an understanding dated 24.04.18 regarding their readiness to draw insulated Aerial Bunched Cable(ABC) instead of overhead bared wire line. Thereby, the area of diversion can be reduced. Hence, the proposal is recommended.

Nilambur,
24.04.2018.


Workad Yogesh Nilkanth IFS
Divisional Forest Officer,
Nilambur North Division.


25/4/18

