



GOVERNMENT OF SIKKIM
ENERGY AND POWER DEPARTMENT

Ref: 33/EHV & SLDC/ACE/EXP/16-17/157 Date: 18/04/2018

MUCK DISPOSAL CERTIFICATE

Under taking is hereby given on behalf of Energy & Power Department, that the muck obtained from cutting works during construction /laying of **"66 KV D/C RORATHANG LILO (PAKYONG – RONGLI) Transmission Line at Sikkim"** Shall be utilized in backfilling of excavated foundation pits/disposed off in the diverted area for the subject transmission line only without causing any damages to the surrounding areas.

For and on behalf Energy & Power Department

Additional Chief Engineer
Energy & Power Department
Government of Sikkim
Gangtok

(Dinesh Kharel)

Additional Chief Engineer (EHV)
Energy and Power Department, Govt. of Sikkim

Muck Disposal Plan

Sl.NO	Components	Compliance
1	Quantity of muck generated for one tower location.	95.16 cum
2	Quantity of muck to be utilized in the project activities.	100%
3	Balance quantity of muck required to be transported to dumping site.	NA
4	Carriage of muck from muck generation to dumping site.	NA
5	Development of dumping site- construction of retaining walls and other structures as per requirement of the site.	NA
6	Rehabilitation of dumping site like leveling, planting of grass, shrubs and tree species.	NA

L.R. Choudhury
Jr. Engineer TLC
Power Grid Corporation of India Ltd.
बल ग्रिड कॉर्पोरेशन ऑफ इंडिया लिमिटेड
Ranipool, Sikkim

Additional Chief Engineer
Energy & Power Department
Government of Sikkim
Gangtok

Muck Disposal Plan

1. Muck generated from tower footing excavation(one leg) :

2.380 m x 2.380 m x 3.0 m	= 16.99 cum
40% for swell factor	= 6.8cum
Total	= 23.79 cum

2. Total muck generated from four (04) legs of one tower footing = 4 x 23.79 cum
= 95.16 cum

3. Total muck generated from excavation used in backfilling of tower foundation in compacted form :
= 100%

Therefore; there is no requirement of transport and dump excess muck to different muck disposal site, the muck generated from the excavation of tower footing shall be utilized in backfilling the foundation of the same tower.

Note: Quantity of muck has been shown for only one tower location with four legs, same will be applicable for rest of the tower footings.

L.A. Choudhury
Jr Engineer (TLC)
Power Grid Corporation of India Ltd.
पावर ग्रिड कॉर्पोरेशन ऑफ इंडिया लिमिटेड
Ranipool, Sikkim

Additional Chief Engineer
Energy & Power Department
Government of Sikkim
Gangtok