

# KERALA STATE ELECTRICITY BOARD LIMITED

(Incorporated under the Indian Companies Act 1956)



Regd. Office: Vydyuthi Bhavanam, Pattom, Thiruvananthapuram - 695004  
web site: [www.kseb.in](http://www.kseb.in), CIN:U40100KL2011SGC027424, GSTIN:32AAECK2277NBZ1



Office of The Deputy Chief Engineer, Transgrid South,  
H.M.T. Colony P.O., Kalamassery - 683 503  
Phone : 0484 2988075, E-mail: [transgridsouth@gmail.com](mailto:transgridsouth@gmail.com)

No.DCE/SRTDT/Forest Clearance/2020-21/1935

Date : 21.10.2020

To

**The Divisional Forest Officer  
Devikulam**

Sir,

**Sub:- Transgrid 2.0- Execution of Kochi Lines Package – ROW Forest Clearance –**  
Reply to the query from the Divisional Forest Officer, Devikulam - reg.

**Ref:-1. Proposal No.FP/KL/TRANS/26406/2017**

- 2.Query no.L/M7-729/2017 dated 08-07-2020 of the DFO, Munnar Division
- 3.Report from the Assistant Executive Engineer, Transgrid TCSD, Pallivasal dated 21.10.2020
- 4.This office letter no.DCE/SRTDT/CLP/2020-21/1722 dated 06.10.2020

With reference to the above, I am submitting herewith the reply to the queries sought vide ref(2) from that office.

**Query:**

**1. JOINT SURVEY/SECOND JOINT VERIFICATION IS TO BE DONE**

- (a) Joint survey/ inspection done with the Munnar forest division surveyor on 24/09/2020 on the required forest land

**2. KML FILE UPLOADED TO BE CORRECTED**

After the joint survey with forest surveyor new .kml file of transmission line inside forest area prepared incorporating with: -

- (a) 220/110 kV MCMV tower locations
- (b) Both sides 2 meters additional ROW required
- (c) 220/110 kV Line drawing
- (d) Forest Janda locations outside the Existing ROW from location KP 55 to KP 59
- (e) Lines plotted with 12.2 mtr minimum height clearance required inside forest.

Soft copy of the new .kml file submitted at the office of the Divisional Forest Officer, Munnar Division.

Additional ROW required from location KP 55 to KP 48 which is about 3048 m/1.2192Ha

3. APPROACH ROAD AREA TO BE ADDED IF NECESSARY

Finally it is decided that manual work to be arranged by the contractor inside the forest locations. So the approach roads are not necessary.

Yours faithfully,

  
Deputy Chief Engineer

Copy submitted to: The Chief Engineer, Transgrid, Shoranur

Copy to: 1. The TA to the Director(T,SO & REES), Vaidyuthi Bhavanam,  
Thiruvananthapuram

2. The Assistant Executive Engineer, Transgrid TCSD, Pallivasal