DIRECTORATE OF ENERGY GOVERNMENT OF HIMACHAL PRADESH SHANTI BHAWAN, PHASE-III, SECTOR-VI, NEW SHIMLA-171009(IIP)

OFFICE ORDER

Directorate of Energy(DOE), Government of Himachal Pradesh, is pleased to accord Techno Economic Clearance(TEC) to Ghator Top SHP(4.98 MW) on Ghator khad a tributary of Chirchind khad in Ravi basin, Distt. Chamba, Himachal Pradesh, allotted to "M/S Chamba Hydro Ventures, Hotel Alps, Dalhousie, Distt Chamba (HP)", at an estimated cost of Rs. 4051.00 lac (Rupees four thousand fifty one lac) only including Interest During Construction (IDC), Escalation, Financial Charges(FC) and LADC @ 1.00% of total project cost with the following stipulations:

- 1.i) The completion cost shall not exceed the above cost except on account of the following:
- a) Interest During Construction(IDC) and Financial Charges(FC) shall be as per actuals but not exceeding the amount as indicated at Annex-I, unless revised by DOE, GoHP while according concurrence under Section-8 of Indian Electricity Act 2003 after review of the financial package.
- b) Change in rates of Indian taxes and duties such as Excise Duty, Sales Tax/VAT, Custom Duty and levy of any other taxes/duties subsequent to issue of Techno Economic Clearance.
- c) Change in Indian law resulting in change in the cost.
- ii) The abstract of the Estimated Cost approved by DOE, GoHP is furnished at Annex-I and the Salient Features of the scheme are at Annex-III.
- 2. The Techno-Economic Clearance(TEC) is subject to the fulfillment of the following conditions:
- Completed cost/Techno-Economic Clearance (TEC) shall not be re-opened due to the following:
 - a) Non acquisition of land.
- b) Non-finalization of Power Purchase Agreement (PPA)
- c) Delay in financial closure.
- ii) The final financial arrangement shall not be inferior to the financing arrangement projected in the Detailed Project Report (DPR) for TEC.
- As proposed by the developer in the DPR, the project is viable by sale of power through Renewal Energy Certificate(REC) mechanism. The cost of the project cleared by the DOE. GoHP is indicative and shall have no binding on the regulator while fixing the tariff. The tariff of the project shall be regulated by the appropriate Electricity Regulatory Commission.
- iv) The public issue expenses, if any, shall be reconsidered at the time of approval of completion cost based on documentary proof and in accordance with Security Exchange Board of India (SEBI) guidelines regarding regulation of public issue expenses.
- v) Fulfillment of conditions stipulated in Central Electricity Authority (CEA)/Central Water Commission(CWC) guidelines in respect of civil works at the stage of detailed designs/execution.
- vi) Any increase in the cost estimate due to design modifications and geological surprises would be absorbed by the Independent Power Producer (IPP) i.e. "M/S Chamba Hydro Ventures, Distt. Chamba (HP)".
- vii) No additional cost shall be allowed due to Resettlement & Rehabilitation (R & R) Plan.
- viii) Normal operation life of the hydro power plant shall be as per provisions of CWC/CEA guidelines or CERC/HPERC regulations.
- The statutory and administrative clearances as per Annex-II shall be obtained before execution/implementation of the project.
- ix) The interconnection point with the State grid antention facilities at the



interconnection point shall be provided, operated and maintained at the cost of the IPP.

The cost of providing and/or strengthening/additions etc. of the system at and beyond the Interconnecting Sub-station which may also include the cost of replacement of ()switchgear/ protection and provision of shunt capacitors, strengthening of bus bars, apart from other works required at injection voltage level and other one or more successively higher voltages, civil works relocation of existing bays etc. shall be recovered by HPSEB Ltd., as per the regulations of HPERC read with the clarifications/decisions by HPERC and/or any other competent authority as may be finally applicable. The share of IPP on this account shall be paid by the IPP to HPSEBL/HPPTCL, as per the final decision of the

Whereas the HPSEBL/HPPTCL shall endeavor to provide the evacuation system at the earliest, the scheduled date for providing evacuation arrangements shall be spelt out in (iz the PPAs on case to case basis inter-alia, keeping in view the time lines indicated in the

The powerhouse generating equipment as well as other electrical equipment to be provided by the developer shall be compatible for parallel operation with the State grid after interfacing. The IPP shall be responsible for any loss of generation on this account.

xiii) O&M charges for maintenance of inter connection facilities at the interconnection substation of HPSEBL/HPPTCL shall be paid by the IPP throughout the period, the IPP runs the project and the same shall be reviewed at the beginning of every financial year.

xiv) For evacuation of power the IPP shall interface this project with 33 KV switchyard of Chirchind SHP by constructing 33 kV line from Ghator Top to Chirchind SHP with 0.15 sq inch "WOLF" conductor on double structure to evacuate the power from Samwara (2.50MW) and Ghator-I(2.20MW) SHPs in joint mode. The cost joint evacuation arrangement shall be shared with other IPPs on proportionate basis.

The project line shall be provided, operated and maintained by the IPP at his cost as per normal conditions after obtaining approval of HP Govt. under Section 68(1) of Electricity

xvi) The above mentioned evacuation arrangements shall be subject to the HPERC approval of "Comprehensive area wise plan for augmenting and establishing of transmission/subtransmission system for evacuation of power from small HEPs" which has already been submitted to HPERC. The Transmission/Distribution Licensee may however also evolve alternate system(s) depending on the site conditions and subsequent developments with the approval of HPERC.

xvii) The IPP shall develop operate and maintain the Project including the dedicated

transmission system subject to compliance with the following:

Grid code and standards of grid connectivity.

Technical as well as Mechanical standards for construction of Electrical lines. a)

Norms of System Operation of the concerned State Load Dispatch Center (SLDC) or b) Regional Load Dispatch Center (RLDC). c)

Directions of the concerned SLDC or RLDC regarding operation of dedicated d)

transmission line.

The IPP shall only be allowed to inject power in HP system with the undertaking that necessary action to provide tele-metering to SLDC shall be provided by them and c) specifications required to be got approved from the office of SE(SLDC), HP Load Despatch Society, Totu, Shimla from compatibility point of view with existing SCADA

xviii) The conditions on these lines shall have to be suitably included by the developer in the

PPA etc. apart from other standard conditions.

- xix) The observations of DOE, GoHP and replies thereof shall form an integral part of the DPR.
- Minimum 15% release of water immediately downstream of diversion structure shall be (XX)ensured all the times including lean season as per Power Policy of HP Govt., 2006 and subsequent amendments thereof. The necessary monitoring equipment as prescribed by

the Pollution Control Board for the same shall be installed by the IPP during execution of

(NSO) LADCHADL amount and activities shall be implemented as per Power policy of HP Govt., 2006 and subsequent amendments thereof.

Wii) The additional 1%(one percent) free power from the project shall be provided and earmarked for a Local Area Development Fund(LADF) as per HP Govt. Notification No. MPP 1 (1) 272005 V dated 30.11.2009.

- XXIII) The TEC is based on the reports and data furnished by the IPP in the DPR and it is presumed that information furnished is correct and has been collected reliably after carrying out detailed field investigations and surveys under the supervision of competent personnel. The scrutiny of DPR does not cover the examination of the detailed designs & working drawings of project components in regard to their structural, hydraulic and mechanical performance & safety which shall be ensured by the project authority/IPP.
- The project shall be completed within 30 months from the date of start of the construction work.
- 4 The completion cost of the scheme shall be submitted to DOE, GoHP for approval within 3 months from the Commercial Operation Date (COD) of the plant.
- 5 The Project Promoters/Project Authorities shall give free accessibility to the officers and staff of DOE, GoHP to have on the spot assessment of various aspects of the project.
- The firm financial package and tie-up of balance inputs/clearances shall be completed () within the period as stipulated in the HP Govt. power Policy, 2006 and subsequent amendments thereof/Implementation Agreement.
- In case the time gap between the Techno-Economic Clearance of the scheme and actual 7 start of work on the project is three years or more, a fresh Techno-Economic Clearance shall be obtained from DOE, GoHP before start of actual work.
- The DOE, GoHP reserve the right to revoke the concurrence if the conditions stipulated 8 above are not complied with to the satisfaction of the DOE/GoHP.

BY ORDER OF THE GOHP

Directorate of Energy, GoIIP, New Shimla-171009(HP).

No. DOE/CE(Energy)/TEC-Ghator Top/2010-子の表。多。 Dated: ちロンコル

Copy for information and necessary action to the:

Principal Secretary (MPP & Power) to H.P. Govt., Shimla-171002 1.

Principal Secretary (NES) to H.P. Govt., Shimla-171002 2.

Secretary, Ministry of Non-Conventional Energy Sources (MNES), Block No.14,CGO 3. Complex, Lodhi Road, New Delhi-110003.

Director, Environmental & Scientific Technologies, Narayan Villa, Near Wood Villa 4. Palace, Shimla-171002.

General Manager, HPPTCL, Borowalia House, Khalini, Shimla-171002. Š,

Chief Engineer (SP), HPSEB Ltd, Vidyut Bhawan, Shimla-171004. 6.

Chief Engineer(Commercial), HPSEB Ltd, Vidyut Bhawan, Shimla -171004. 7.

Chief Executive Officer, Himurja, 8A-SDA Complex, Kasumpti, Shimla-171009. 8.

M/S Chamba Hydro Ventures, Hotel Alps, Dalhousie, Distt Chamba (HP).. 9.

Chief Engineer.

Directorate of Energy, GoHP,

New Shimla-171009(IIP).

Ghator Top SHP(4.98MW) in Distt Chamba of Himachal Pradesh allotted to "M/S Chamba Hydro Ventures, Hotel Alps, Dalhousie, Distt. Chamba (HP)"

ABSTRACT OF COST ESTIMATE

Sr. No.	Description of works	Amount
1	Civil works i/c other Misc. Expenses	(Rs. in Iac) 2328.76 Price Level
2	Electro Mechanical works	1054.26 March, 2011
3	Transmission works Sub Total (a)	125.00 3508.02
(b) .	Interest During Construction (IDC)	309.20
2	Escalation	164.36
3	Financial Charges(FC) Sub Total (b)	29.26 502.82
	Total (a+b)	4010.84
(c)	LADC @ 1.00 % of (a1-b)	40.11
	GRAND TOTAL (a+b+c) Say	4050.95 Rs. 4051.00 lac

(Rupees four thousand fifty one lac only)

Chief Engineer,

Directorate of Energy, GoHP, New Shimla-171009.

Ghator Top SHP(4.98MW) in Distt Chamba of Himachal Pradesh allotted to "M/S Chamba Hydro Ventures, Hotel Alps, Dalhousie, Distt. Chamba (HP)"

LIST OF STATUTORY AND ADMINISTRATIVE CLEARANCES REQUIRED

C. No			
	ITEM	AGENCY	REMARKS
1.	WATER ABAILABILITY	1. State Govt. 2. CWC	Interaction between State Govt. Deptt. & CWC required. Relevant Irrigation Act of the State & Central Water Commission.
2.	SEB CLEARANCE	1. SEB. 2. State Govt.	Section 44, E(S) Act, 1948 Repealed by Electricity Act 2003.
3.	POLLUTION CLEARANCE WATER AND AIR	State/Central Pollution Control Board	Water (Prevention & Control of Pollution) Act, 1974 Air (Prevention & Control Pollution) Act, 1981.
1	FOREST CLEARANCE	1. State Govt 2. Min.of E&F G.O.I.	Coordination with State Forest Deptt./ Min. of Environ. & Forest (MOE&F) regarding Forest (Conserva-tion) Act, 1980.
5	ENVIRONMENT & FOREST CLEARANCE	1. State Govt 2. Min.of E&F G.O.I.	As per item (3) & (4) and Govt. Policy in force.
6.	REGISTRATION	Registrar of Companies.	Under Indian Companies Act, 1950.
7.	REHABILITATION & RESETTLEMENT OF DISPLACED FAMILIES BY LAND ACQUISITION	1. State Govt 2. Min.of E&F G.O.I.	`
8.	EQUIPMENT PROCUREMENT	DGTD,CCI& E	Import & Export Acts.

Chief Engineer, Directorate of Energy, GoIIP, New Shimla-171009.

harty-

1. LOCATION

State

Destrict/fehsal

Proposal

Acres Road

Rad

Auport Géographical co-ordi**nate**s

Latitude Longitude .

SOI topo sheet

SALIENT FEATURES

Hunachal Pradesh Chamba/Bharmour

Chator, Badhar, Chatrari, Durghatti.

Weir site on Chintor klind at 1st. (2735ru and Power house on right bank at 1st. (2080 m

nem village Ghator.

45 km from Chamba on Chamba Bharmon State Highway upto Durghatti. Further a metalled road has been constructed upto the Chatrari village at 3 km distance and another road is under construction upto the Ghator village.

Nearest BG station at Pathankot(Punjab). Nearest airport is at Gaggal in Kangra.

Weir Site Power House Site 32" - 22' - 33" N 32" - 23' - 56" N

76° - 23' - 02" E 76° - 23' - 01" E

52 - D/7

2 HYDROLOGY AND CLIMATE

Same to khad Tabutars of Basin

Catchment area upto diversion site

Snow Catchment Area Average Yield (MCM) Maximum / Minimum Yield

Average annual rainfall .

Design discharge

Design Flood

Maximum temperature Minimum temperature Ghator khad

Chirchind khad/Ravi basin

12.00 sq km 7.00 sq km 25.87 (MCM) 34.99 / 16.05 (MCM)

34.997 10.03 (MCM)

935.13 to 1154.72 mm at Chamba.

0.96 cumecs 128.00 cumecs 30° C

-10° C

3 PROJECT COMPONENTS

3.1 DIVERSION WEIR

Type

River bed level

Size

Drop type Trench Weir

EL ± 2735.00 m

10.00 m long x 1.50 m wide

3.2 CONVEYANCE CHANNEL

Type

Size Length Slope Box type

 $0.80~\mathrm{m} \ge 0.90~\mathrm{m}$

45.00 m ! in 150

3.3 DESILTING ARRANGEMENT

Type

Size
Particle size to be excluded.

Hushing discharge

Underground, Conventional Hopper Type 22.00 m × 4.00 m × 1.84 m(effective)

All particles down to 0.20 mm size.

0.30 cumecs

Size of silt flushing pipe

3.4 WATER CONDUCTOR SYSTEM (Head Race Tunnel)

Size

D Shaped tunnel 1.80m x 2.10 m

Length

545.00 m

Slope Design discharge 1 in 800

Velocity

0.96 cumecs 1.02 m/sec.

3.5 FOREBAY

Type

Surface

Size

17.00 m x 5.00 m x 2.00 m(effective)

FR1

EL± 2733.47 m

MDDL.

EL± 2731.46 m

C/L of penstock at forebay intake

EL± 2730.00 m

3.6 PENSTOCK

Type

Size

Thickness.

Length

Velocity

Number of branches

Size of branch penstock

One number 600 mm dia

Varying between 8 mm to 24 mm.

Three

450 mm dia. Each

3.7 POWER HOUSE

lype

Location

Installed capacity

Size of power house

Gross Head

Net head

Max. Tail water level

Min. Tail water level

Turbine(s)

Type

Number

Rated output

Generator(s)

. Type

· Number ·

Capacity

· Power factor

Rated voltage

 Frequency Overload capacity Circular, Surface steel penstock

1550.00 m

4.04 m/sec.

Surface

Right bank of Ghator khad at EL± 2080m

4.98 MW(3 units of 1.66 MW each)

36.00 m x 11.50 m x 12.50 m

653.47 m

625.00 m

EL ± 2080.00 m

EL ± 2078.50 m

Horizontal shaft Pelton

Three

1729.17 kW each

Horizontal shaft Synchronous

two

1660 KW each

0.9 lag

3.3 kV 50 Hz.

20 %

3.8 TAIL RACE

Type

Size

Length

cut and Cover channel

1.20 m × 1.50 m

Chief Engineer, Directorate of Energy, GoIIP,

New Shimla-171009.