





TOTAL (1+2) = 60.72+11.24 = 71.96 SQM OR SAY = 0.0072 HA.

| SCHEDULE OF TANK AND PUMP | | | | CONST. DETAIL OF U/G TANK | | | |
|---------------------------|----------|------------|---------------------|---------------------------|-------|---------|-----|
| PRODUCT | CAPACITY | NO OF TANK | MPD NO OF NOZELS | CAPACITY | (L) | (D) | PL1 |
| MS | 15KL | 1NO. | 4NOS | 15KL | 5.00M | 2.010Mφ | 6MM |
| HSD | 20KL | 1NO. | 4NOS | 20KL | 6.75M | 2.012Mφ | 6MM |

1. Certified that there is no other structure will be erected nor any other service rendered except that connected with the petrol pump without the prior approval of P.W.D.
2. Certified that there is no road crossing within 100m between the tangent points of the curves of the side road and that of the fuel tank.
3. Certified that there is no objection from road point of view for the installation of this pump.
4. Certified that there is no objection from the point of view of the improvement of the road.
5. Certified that no other petrol pump exists within the distance of 300m on either side of the plot.
6. Certified that the berm portion is not included in the area of land to be leased from P.W.D. for approach road but is to be metalled by the corporation.
7. Certified that all the conditions laid down by the Govt. of India and inc from time to time with regard to the location and construction of petrol pump service stations have been complied with entire construction will be on corporation land.
8. No drain, sewer or structure within 15m from approach ground tank.
9. Section pipes, under drive-way housed in pipe sleeves.
9. Electric fitting conform to ISS code no 2148 for dispensing pumps only.
10. D.P.S. board 1.50m high from floor level and will not be kept under lock and key.
11. Tanks fed by tank lorry.
12. No hedges and plants more than 60m high should be grown around the buffer strip.
13. There should be a standing space inside the station for vehicles to wait for their turn.
14. In & Out are put up guide vehicles during the day and are property fit up to guide them at night.
15. No smoking sign, fire extinguisher and fire buckets provided at site.
16. 40 m x 10 Vent pipes, 100 mm high from ground level and 100 mm dia. The open end of Vent pipes covered with 10 mesh layers of net conforming to fire gauge of 10mm per linear cm.
17. Certified that buffer should not have any installation inc. under ground tanks etc.
18. Certified that the kerbing along buffer is to be made by corporation.
19. Certified that the location of the berm at the most of the road to be provided.
20. Certified that there will not be any hindrances from over head lines & poles.
21. Certified that the surplus water will not be disposed off in P.W.D. land.
22. Certified that all clearances/approvals from n.p.c and other relevant Govt. departments have already been obtained.
23. Certified that there is no court case pending in any court of India on this premises and decisions.
24. Certified that this is not a resentment case.

| | |
|-----------------------------------|-------------------------------|
| AREA STATEMENT TOTAL PLOT AREA | 1607.18 SQM |
| VILLAGE | JAISINGHPUR |
| MUSTIL/KILA NO. | 61/1/2,8/2.12/2, 13/1,18/2 |
| TEHSIL | NUH |
| DISTT. | NUH |
| State | HARYANA |
| NEAREST POLICE STATION | JAISINGHPUR |
| NEAREST RAILWAY STATION | PALWAL |



| | | |
|-----------------------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------|
|  IndianOil | Indian Oil Corporation Limited (Marketing Division) Gurgaon Divisional Office, | |
| | PROJECT :- SITE & LAYOUT PLAN FOR PROPOSED RETAIL OUTLET AT VILLAGE JAISINGHPUR, ON HODEL NUH ROAD (MDR-132), TEHSIL AND DISTRICT NUH, HARYANA. | |
| DRAWN: SEHGAL CHKD | DRG. NO. DATE : | DATE |
| APPRD | SCALE : 1:200 | DRAWING NO. |
| PREPARED BY: SEHGAL ASSOCIATES 8607798320 | | NUMBERS CROSSED OUT ARE SUPERSEDED DRAWING |