



M-80,
M-80

HARYANA PUBLIC WORKS DEPARTMENT
(BUILDING & ROADS) BRANCH, NARNAUL
Ph. No. 01282-251267 (O), Fax No. 01282-250037 (O).
E:mail ID: pwd-eeepd-narnaul@hry.nic.in
Website: <http://haryanapwd-bandr.org>

416

To

The Sub Divisional Officer,
Construction Sub Division,
HVPNL, Rewari

No. 1979

Dated: 4-5-21

Subject:

Providing No Objection Certificate for construction of 132 D/C line from proposed 220 kV S/S, Deroli Ahir to 132 kV S/S, Ateli with 0.4 sq inch (Zebra) ACSR conductor with LILO of one circuit at 132 kV S/S Munida Khera line.

Ref.:

Your office memo No. 262 dated 29.04.2021

In this connection, It is intimated that this office has no objection of above cited subject work subject following condition.

1. Electric line passes over PWD road should be shortly as per guide line of electricity act. 2003.
2. No poles should be erected in PWD Land / Row of road.
3. Any type of damage on PWD road must be avoided in future of road will be raised/widened, the poles will be raised/shifted by HVPNL at this own cost.
4. During crossing of road safety work should be ensured.

DA/Nil

Executive Engineer,
Provl. Divn. PWD B&R Br.,
Narnaul.