

HIMACHAL PRADESH STATE ELECTRICITY BOARD LIMITED.

(A State Govt. Undertaking)



Registered Office: Vidyut Bhawan, HPSEBL, Shimla-171004 (H.P.)
Number (CIN) U40109HP2009SGC031255
GST No. HPSEBL 02AACCH4894EHZB
Telephone/Fax Number 0177-2803600, 2801675 (Office), 2658984 (Fax)
Website address www.hpseb.com
Email cmd@hpsebl.in & directorfa@hpseb.in



No:-HPSEBL/TED/FCA Shakti marror /2022-23 - 1036-1037 Dated: 16/07/2022

To

The Divisional Forest Officer,
GNHP, Division, Shamshi.

Subject: Diversion of 8.1872Hac Forest Land for the construction of 11KV HT line to the Un -electrified village Shagore, Shakti and Marror in Banjar Block Distt Kullu H.P.

Ref Your office Endst No. 2785 dated 14.07.2022.

Sir,

“Jai Hind”

In this regard, please find here with the point wise reply to the observations raised by State Govt. conveyed vide Nodal Officer Cum Addl Pr. CCF(FCA), O/o Pr. CCF, HP Shimla-1 endorsement no. Ft 48-3662/2017(FCA).

Reply to Point no. 1

Out of three routes for which the survey was conducted the selected route R-1 for proposed 11 KV line on insulated cables on poles, have minimum trees in its alignment and least damageable to environment as per joint inspection report already submitted with the case, however copy of same is again annexed here with for ready reference please.

Reply to point no 2


This point is not applicable for said proposal.

This is for your kind information and further necessary action please.

Yours sincerely

DA:- as above


g/k


16/7/2022
Sr. Executive Engineer,
Electrical Division,
HPSEBL, Thalout.
xenedthalout@gmail.com
(9459527645)

Copy forwarded to :

1. The Superintending Engineer, Operation Circle HPSEBL Kullu.

g/k


16/7/2022
Sr. Executive Engineer,
Electrical Division,
HPSEBL, Thalout.
xenedthalout@gmail.com
(9459527645)

Joint Inspection Report

Full Title of the Project:- Construction of 11 KV H.T. line to the Un-Electrified Villages Shagor, Shakti & Maror in Banjar Block District Kullu under ESD HPSEBL, Larji.

Date of Inspection: - 17 & 18.08.2016.

Report:- We the undersigned conducted the Joint Inspection of the Line route of the proposed Construction of 11 KV H.T. Line underground cable and insulated cable on poles to the Un-electrified villages Shagor, Shakti & Maror in Banjar Block, District Kullu under ESD HPSEBL, Larji (H.P.) (Pole No. 1 to Pole No. 248).

The High tension line shall pass through the revenue villages Faati Lapah & Gara Parli in Tehsil of Sainj. The forest land of Shamshi, under Forest Division GHNP Shamshi is involved.

Features of High tension Line /underground cable and cable on poles:-

i)	Type and Voltage of High Tension Line :	11 KV H.T. Line
ii)	Length of Trans. Line:	12.118 KM
iii)	Number of Poles:	248 Nos.
iv)	Width of Right of Way adopted:	7 Mtr.
v)	Area of Forest land involved:	8.18.72 Ha
vi)	Bifurcation of forest land as per zones:	
	a) Eco-development Zone of GHNP:	0.4627 Ha
	b) GHNP Zone:	4.6501 Ha
	c) Sanctuary Zone (Sainj Wildlife Sanctuary):	3.0744Ha
vii)	Non Forest Land (Private):	0.2954 Ha
viii)	U/Ground Cable area in GHNP:	1.4112 Ha

The three alternate routes were examined as R1, R2 & R3 and Route No. R1 was found to be most suitable for construction of 11 KV H.T. Line underground & insulated cable on poles to the Un-electrified villages Shagor, Shakti & Maror in Banjar Block District Kullu under ESD HPSEBL, Larji (H.P.). R1 involving least number of forest trees to be felled and least forest area to be diverted as compared to Routes R2 & R3.


The High Tension line a linear project and possible steps are taken to avoid the route alignment through forests. In case, where it

becomes unavoidable due to geography of terrain the alignment is made in such a way that the route through the forest is the barest minimum. The line route chosen is the best one and there is no other better proposal. Transmission line laying project is not involving any disposal of solids effluents and hazardous substance in land, air and water. Therefore, the project is justified.

Er. P.R. Bodh

Addl. Superintending Engineer
HPSEBL, Division
Thalout

(User Agency)


Divisional Forest Officer
HP Forest Division
GHNP Shamshi
District Kullu (H.P.)


Sub Divisional Magistrate
Sub Divison Banjar
District Kullu (H.P.)