

Check list No-3
(Online-FORM-A, PART-I-B1)

FORM-A
Form for seeking prior approval under section-2 of the proposals and by the
State Government and other authorities.

PART-I

(To be filled up by the user agency)

Sr. No	Project Details	
1	(i) Short narrative of the proposal and project/scheme for which the forest land is required.	<p>Erection of 66KV Line with Dog conductor on D/C Panther Tower line to 66kv Jirval,Nandgam and Ghanveri sub-station</p> <p>Of <u>village- of 66KV Jirval line</u> are Kajli, Vard Talat, Bhandarkatchh and Jirval</p> <p><u>Village of 66Kv Nandgam line</u> are Dabkhal and Nandgam</p> <p><u>Village of 66Kv Ghanveri line</u> are Astol ,Pendhardevi ,Eklera, Bamanwad , Terichikhali, Ghanveri</p> <p>All villages of Ta-Kaprada, Dist- Valsad</p>
	(ii) Map showing the required forest land boundary of adjoining forest on a 1:50.000 scale map	Refer Annexures 4&5.
	(iii) Cost of the project	<p>Jirval-650 Lacs</p> <p>Nandgam-715 Lacs</p> <p>Ghanveri-925 Lacs.</p> <p>Total -2290 Lacs.</p>
	(iv) Justification for locating the project in forest area	The final route has been selected so as to technically it is unique feasible shortest route.
	(v) Cost benefits analysis (to be enclosed)	Refer annexure 12A, 12B, 12C
	(vi) Employment likely to generated.	Basically this line is meant to line shall boost up all sector of society by eliminating power cut/load shedding and solve low voltage problem.

2.	Purpose wise breakup of the total land required.	Transmission route cover the reserved forest land is approximately as Under (1) In Jirval line - 1205 Meter length we required right of way 18 Meter (18 X 1205) = 21690 sq.meters i.e-2.169 Hac (2) In Nandgam line - 3965 Meter length we required right of way 18 Meter (18 X 3965) = 71370 sq.meters i.e-7.137 Hac (3) In Ghanveri line - 6850 Meter length we required right of way 18 Meter (18 X 6850) = 123300 sq.meters i.e-12.330 Hac Total land Required- 21.636 Hac. in 66KV Dog line We proposed diversion of forest land for 66KV Transmission line which will be laid above ground as per IE rules requirement to ensure safety
3.	Details of displacement of people due to project id any.	
	(1) Number of families.	None
	(2) Number of schedule cast & schedule tribe families.	No
	(3) Rehabilitation plan (to be enclosed)	N/A
4.	Whether clearance under environment protection Act 1986 required (Yes/No)	N/A
5.	Undertaking to bear the cost of raising and maintenance of Compensatory a forestation as well as cost for protection and regeneration of safety Zone, etc. as per the scheme Prepared by the state Government (undertaking to be enclosed)	Annexure 8B
6.	Details of certificates/documents enclosed as required under the instruction	

For Gujarat Energy Transmission Corp. Ltd.

P.N.PATEL

Executive Engineer (Const.)

GETCO, Navsari