



**::TAMIL NADU TRANSMISSION CORPORATION LTD::
(A SUBSIDY ENTITY OF TNEB LTD)**

From
Er.K.N.Santhini, B.E.,
Superintending Engineer,
General Construction Circle,
182, Dr.Subbarayan road,
Tatabad, Coimbatore – 12.

To
The Principle chief conservator of forest,
Panagal Maaligai ,
Saidapet.
Chennai-600015

Lr.No.SE/GCC/CBE/AEE/Moni/F.Parali SS / D.522/19, Dt.05.07.2019.

Sir,

Sub: TNEB – TANTRANSCO – Coimbatore region –Forest (Conservation)
Act,1980- **Utilising the existing 230 KV transmission corridor
(since 1965)** Conversion of Existing 230 KV SC line on SC Tower with
Kundha Conductor into 400 KV Double Circuit line on Double Circuit
Tower with Twin HTLS (ACCC Drake) conductor from Kundha PH 3 (Loc .01 o 56) on Kundha PH 3 – Karamadai Feeder – Nellithurai
Reserved Forest of Coimbatore Division – Forest Permission - certain
Particulars - Regarding

Ref: (1) PCCF/Chennai's Letter No.TS3/29182/2019 Dt.28.06.20198

(2) Proposal No.FP/TN/TRANS/40633/2019 Dt.11.06.2019

(3) Lr No: SE/GCC/CBE/AEE/Moni/F: Parali SS /D:520/19 dt 02.07.2019

With Reference to (i) Cited above, following Particulars are furnished:

- 1) The Area statement indicating the length and Breadth of forest land required to be diverted for the subject Transmission line to an extent of 15.15 Ha has been uploaded
- 2) The Area details forest land to be diverted is enclosed. The existing Transmission line corridor was laid during 1965. Hence forest clearance approval lease obtained from forest department.

- 3) Authorisation letter issued by Chief Engineer/Transmission Project II/Trichy to Superintending Engineer/GCC/Coimbatore, in Support of the competence/authority of the person mailing the application to make application on behalf of user agency has been uploaded.
- 4) 3 no segment of the existing corridor have been marked in the survey of India TOPO Sheet and Uploaded.
- 5) Tables Showing GPS reading of the Transmission line /forest area diversion requested and also for existing tower locations have been uploaded.
- 6) A detailed Justification report for forest area diversion has been uploaded.
- 7) Cost benefit analysis is not required for this Project.
- 8) Letter has been addressed from this office to District Collector/Coimbatore vide ref (3) requesting to Issue Certificates for
 - a) Completion of Process for Settlement of Rights Under the forest right Act 2006 on the forest land proposed to be diverted under section (K) and
 - b) No alternate non forest land is available for the project.This will be submitted immediately on receipt of same from District Collector/Coimbatore.
- 9) The following Certificates by the user agency have been uploaded.
 - i) Certified that no violation of the provision of forest Conservation Act,1980 has been occurred by the user agency in the project proposed area.
 - ii) Certified that no alternate suitable non forest land is available for the project and demands for forest land for the project is minimum and al alternative have been examined and not feasible.
- 10) An Undertaking to Pay the cost towards lease rent as fixed by the Forest department at the time of sanction along with any escalation for the forest land to be diverted of the above project has been uploaded.

Hence it is requested that the forest proposal seeking permission for diversion of 15.50 ha for **"Utilising the existing 230 KV transmission corridor (since 1965)** Conversion of Existing 230 KV SC line on SC Tower with

Kundha Conductor into 400 KV Double Circuit line on Double Circuit Tower with Twin HTLS (ACCC Drake) conductor from Kundha PH 3 (Loc .01 o 56) on Kundha PH 3 – Karamadai Feeder” may please be arranged to be issued Please.

Yours faithfully,

for B. Prabhakar
Staff
Superintending Engineer
General Construction Circle
Coimbatore – 12.

Copy submitted to the Chief Engineer / TP II / Trichyf For Kind information please

Copy Additional Principal chief Conservator of Forest/Coimbatore.

Copy to District Forest Officer/Coimbatore District. -

Copy to the Executive Engineer / TLC / Mettupalayam – For follow up action