

TO

Divisional Forest Officer

Chamba forest division


Chamba (H.P) 176310

Subject: Diversion of 0.9854 hectare of forest land in favour of ometa hydro project House no.73 Raipur khurd Chandigarh 160003. for the construction of braguna small hydro project (1.50 M.W.)HEP WITHIN THE JURISDICTION OF Chamba forest Division Distt. Chamba Himachal Pradesh (online Proposal NO. FP/HP/HYD /44517/2020).

This is reference to latter dated 29/6/2022 on the subject cited above. In this connection we have submit as under:-

In response to your observation raised vide your latter under reference, We have submit point wise clarification as under:-

- 1) As per the moef guide line the minimum width of ROW of underground transmission line 33kva (double circuit) is 1.20 meter but as per record of revenue department the minimum measurement is one karam i.e.1.42 meter. As per revenue department it is not possible to measure 1.20 meter on the latha or tatima. so it is requested to that the nodal office Himachal Pradesh Government and Government of India Solve this issue. User agency attach undertaking.
- 2) As per the moef guide line the minimum width of ROW of underground transmission line 33kva (double circuit) is 1.20 meter but as per record of revenue department the minimum measurement is one karam i.e.1.42 meter. As per revenue department it is not possible to measure 1.20 meter on the latha or tatima. so it is requested to that the nodal office himachal Pradesh Government and Government of India Solve this issue. User agency attach undertaking.
- 3) layout plan showing the all component in distinct colours of the project is enclosed herewith.
- 4) Information sought point no.4 reply, we have inform you that no such study ravi river basin has been carried out by the Government of himachal Pradesh (DOE) As yet.as and when such such data shall be collected,the same shall be shared with you.
- 5) Should be removed by DFO.

  
SIGNATURE OF UA  
M/s Ometa Hydro Pvt. Ltd.  
M/S Ometa hydro pvt.ltd.

To

The Divisional Forest Officer,  
Chamba Forest Division,  
Chamba

Subject: Diversion of 0.9854 hectare of forest land in favour of ometa hydro project House no.73 Raipur khurd Chandigarh 160003, for the construction of braguna small hydro project (1.50 M.W.)HEP WITHIN THE JURISDICTION OF Chamba forest Division Distt. Chamba Himachal Pradesh (online Proposal NO. FP/HP/HYD /44517/2020

Reply point no. 1&2

Sir,

It is to inform to you through this letter that transmission line ROW for underground 33 KV transmission line is 1.20m which is not possible to measure because the measurement scale of revenue department is 1.42m. It is not possible to measure 1.20m on the Latha or Tatima. So it is requested to that the Nodal Office of H.P. Govt. please solve this issue so we can complete the documents and start the construction work. So you are kindly requested to go through the matter.

Thanking you

  
M/s Omata HYDRO Pvt. Ltd.  
M/s Omata Hydro Pvt. Ltd.