


HIMACHAL PRADESH STATE ELECTRICITY BOARD LTD.

No. RED/PS-Power House/2014-15 - 1191

Dated: - 22.5.14

To




M/s Him Prabha Power Pvt. Ltd.
Village Karnguhi, PO,. Panthera, Tehsil Ghumarwain,
Distt. Bilaspur (HP).

Subject: - NOC for construction of 4.8 M.W. Kurpan-II, SHP.

Sir,

With reference to the above cited subject the requisite NOC for the construction of 4.8 M.W. Kurpan-II SHP is granted on the following terms and conditions.

1. The adequate clearance of transmission line be maintained as per Indian Electricity Rule No. 87 (Indian Elect. Rules 1956) from the existing HT lines.
2. The proper guarding be done on HT/LT lines crossing, road and river crossing.
3. While construction of transmission line proper shutdown be taken from the competent authority.


 Sr. Executive Engineer,
 Electrical Division HPSEBL,
 Rampur Bushahr.