

**HIMACHAL PRADESH STATE ELECTRICITY BOARD LIMITED.**  
**\*\* A STATE GOVERNMENT UNDERTAKING \*\***

No. RHC/DB-13/2013-14- 13684-85  
To

Dated:- 28-3-2014

M/S Himprabha Power Pvt.Ltd.  
Village Karnguhi, PO Panthera ,  
Tehsil Ghumarwin ,Distt. Bilaspur  
Himachal Pradesh .


**Subject:- Approval of 4mt. ROW for FCA for Lower Kurpan-II (4.8 MW).**

Ref:- Your office letter No. Himprabha /SHP/Lower Kurpan-II/12 dated 24.02.2014.

D/Sirs,

In this context , it is intimated that as per construction design /drawing of 22 KV HT line on double pole structure submitted by your office letter under reference, the minimum required ( right of way ) clearance of above line is 3.928 mtrs. for tree branches or leaves as per Indian Electricity Rules / Standard practice of HPSEBL. This is for your kind information please .

Yours Sincerely,

  
(Er.S.N.Upreti)  
Superintending Engineer ,  
Operation Circle HPSEBL,  
Rampur Bushahr.  
Phone No.01782-233126

Copy forwarded to the Divisional Forest Officer Rampur for information w.r.t. letter referred above please .

(Er.S.N.Upreti)  
Superintending Engineer ,  
Operation Circle HPSEBL,  
Rampur Bushahr.  
Phone No.01782-233126