



Ajmer Vidhyut Vitran Nigam Limited

Corporation Identification Number(CIN) – U40109RJ000SGC016482

Registered Office: Vidhyut Bhawan, Panchsheel Nagar, Makarwali Road, Ajmer-305004

Office of The Assistant Engineer(O&M), Kotra

PHONE&FAX02958227421,EMAIL:udp.aen.11@gmail.com,websitewww.avvnl.com



No./AVVNL/AEN/(O&M)/KTR//2021-22/D- 671

Date- 26/07/2021

M/s. Wolkem Industries LTD.
Near Uparla & Nichala Khera
Teh-Bali & Kotra
Dist- Udaipur & Pali(Raj.)

Subject- Regarding Consent for Erection of 11KV Line from 33/11 KV Bekariya GSS to Wolkem Industries LTD. Kheratarla Mine for new connection.


- Reference-
1. Your application on Dated 23.02.2021 for HT connection.
 2. This office letter no. 1585 Dated- 24.02.2021.
 3. This office Reminder letter no. 09 Dated- 07.04.2021.
 4. Your office letter no. 144 dated- 23.07.2021.

On the above cited subject & reference you have applied for new HT electric connection having Contract Demand 275 KVA & Connected load 883 HP for Kheratarla Mine situated at Near Uparla & Nichala Khera Teh-Bali & Kotra Dist-Udaipur & Pali(Raj.). In this connection New 11 KV Line erection required from 33/11 KV GSS Bekariya to Your Mine. But New 11 KV Line to be Passing from Forest Area Nathional Highway(NH-27). So NOC Required from Both Department.

In this regard a joint survey done by Undersigned, JEN Devla & your Company representative for erection of 11 KV Line & 03 Nos Alternative Route surveyed as shown in SOI TOPOSHEET MAP submitted by You. But as per Technical Feasibility & Physical Condition only Alternative Route No.-1 recommended for erection of 11 KV Line due to following reason :-

1. Alternative Route No-1 Passes over govt. land & Non Populated area. Its approx length 4545 Meter shall be falls in Non Forest land & 5500 Meter in Forest land.
2. Alternative Route No-2 Passes over Populated area & mostly Agriculture Land. So ROW problem will be occurred in erection of Line.
3. Alternative Route No-3 Passes over Populated area & along the National Highway (NH-27). So Commercial activities may be effected in Future.


So recommendation of Alternative Route No-1 with attested copy of SOI TOPOSHEET MAP (Copy enclosed) is submitted for further necessary action.


(Umesh Kumar Dubey)
Assitant Engineer(O&M)
AVVNL Kotra

Copy submitted to the following for information & further necessary action :-

1. The Senior Engineer (O&M) AVVNL Udaipur.
2. The Executive Engineer (R-II) AVVNL Udaipur.


(U.P. BAHADIYA)
DIRECTOR


(Umesh Kumar Dubey)
Assitant Engineer(O&M)
AVVNL Kotra