








LAYOUT PLAN
SCALE 1:250



KEY PLAN
SCALE 1:500



SITE INFORMATION	
MUNICIPALITY NO.	18A-0769
VILLAGE	RANCH
TENSHI	BARRINGTON
DISTRICT	HAMILTON DISTRICT
RAILWAY STATION	BARRINGTON
POLICE STATION	BARRINGTON
POST OFFICE	CUMMERVILLE
STATE	UTAH
FIRE AREA	1224

NOTES:-

- 1) THE VENT PIPE IS TO BE PROVIDED WITH A BRASS/STAINLESS STEEL WIRE GAUGE OF 1/16" MESH PER LINE INCHES AND THEIR ENDS ARE COVERED WITH A CAP.
- 2) ALL FLANGE POINTS OF THE TANKS ARE PROVIDED WITH CAM LOCK COUPLING AND ARE PROVIDED WITH AIR TIGHT GASKETS. AIRTIGHT GASKETS ARE PROVIDED FOR ALL FLANGE POINTS. ALL FLANGE POINTS ARE TO BE PROVIDED WITH AIR TIGHT GASKETS.
- 3) ALL ELECTRICAL FITTINGS PROVIDED ARE FLAME PROOF TYPE.
- 4) ALL DOORS AND WINDOWS OF THE BUILDING ARE TO BE PROVIDED WITH AIR TIGHT GASKETS.

TANK VOL.(LIT.)	TANK DIA.(M)	TANK LENGTH(M)	HEAL VOL.(LIT.)	AIR SPACE (LIT.)
15000	1.88	6.0	22200.3495	2200.3495
20000	2.01	7.0	44524.2188	4524.2188

21) THE CONSTRUCTION OF RETAIL OUTLET OF R/O AS PER IRC
APPROVAL NO. 12/83 AND IRC RECOMMENDATION ARE BEING FOLLOWED.

1) IT IS CERTIFIED THAT ALL THE CLEARANCE APPROVALS FROM MOP & OTHER
RELEVANT GOVT DEPARTMENTS HAVE ALREADY BEEN OBTAINED

2) IT IS CERTIFIED THAT ALL THE IRC GUIDELINES ARE MET

3) IT IS CERTIFIED THAT TO BEST OF OUR KNOWLEDGE THERE IS NO COURT CASE
PENDING IN ANY COURT OF INDIA, AGAINST THESE PREMISES AND DEPARTMENT

4) IT IS CERTIFIED THAT THIS IS NEW RETAIL OUTLET

5) IT IS CERTIFIED THAT ALL THESE FACILITIES HAVE BEEN PROVIDED AND
EXACTLY AS PER THE DRAWING

6) IT IS CERTIFIED THAT NO HIGH TENSION LINE/ELECTRIC LINE IS PASSING OVER THE
PREMISES

APPROVAL STAMP

ESSAR **ESSAR OIL LTD.**

TITLE	FUELING STATION LAY OUT PLAN
-------	------------------------------

DRAWN BY:		DATE:
CHECKED BY:		

ORG NO. EOL-M/NZ/UP-C-1934	RE
----------------------------	----