

CHECK LIST SERIAL NUMBER - 10

JUSTIFICATION FOR LOCATING THE PROJECT IN THE FOREST AREA TO BE SUBMITTED BY USER AGENCY AND COUNTER SIGNED BY DISTRICT FOREST OFFICER


1257

FOREST AREA

There are construction of 2 no. 220 kV Sub- Station i.e at sector -32 Panchkula and at Pinjore are under construction and likely to be completed by August 2017. The under construction Sub-Stations are to be fed from 400 kV Sub Station Naggal Barwala (PGCIL) through proposed 2 no. 220 kV feeding lines, having 19.7 km of total route length out of which 6.4km is proposed to pass through the vast urbanization area by HUDA and as well as sensitive defense installations. The part route is proposed to pass through the Wild life sanctuary as no other option for construction of 220kV D/C lines from 400 kV Naggal, Barwala (PGCIL). As shown in the G.T survey sheet of the area there is no alternate route is available for the construction of the lines due to premises of TBRL (Defense) and its shooting range fallen at the adjacent of Wildlife Sanctuary in one side and another side the area of Punjab State existed. Therefore alternate route marked in red colour is not possible to execute. It is therefore requested the already approved routes as marked in violet colour in G.T survey sheet may kindly be approved and necessary permission to carry out the work in Wildlife Sanctuary area may be provided so that works may be completed in time in public interest.

C/S


Signature of User Agency



  
SDO Const. S/Divn.  
HVPN, Panchkula

**Executive Engineer**  
Xen Transmission System  
**HVPN Division HVPN**  
Madanpur, (Panchkula)

Countersigned

  
District Forest Officer  
Panchkula (Haryana)  
Morni Pinjore, Forest Divisor  
Pinjore 134102

6/8/2020

